

New Orleans Fire Department  
317 Decatur St. N.O. LA 70130



Fire Prevention Division  
(504) 658-4770 fax (504) 565-7851

REVIEWED  
N.O.F.D  
FIRE PREVENTION  
PLAN EXAMINER  
*[Signature]*  
DATE 25 January 2021

Date 07 JANUARY 2021

Contact Person: Pat Swilling

Project Name: 1609 and 1613 Baronne Apt

Address: 4901 Chef Mantuer Hwy  
New Orleans, La 70126

Project Address: 1609 and 1613 Baronne  
New Orleans, LA

19-36787-NEWIC  
20-41384-NEWIC

Dear Sir/ Madam:

Please be advised that the above referenced plans and specifications have been reviewed by the Fire Prevention Division as indicated below.

- Location of Fire Command Stations (if High-rise Building): Not High rise building -not applicable
- Location of Fire Alarm Control Panel: ON FIRST FLOOR, FRONT ROOM OF COMMERCIAL SPACE, ON RIGHT WALL IN FRONT OF RESTROOM DOOR.  
Remote Annunciator Panel: N/A
- Sprinkler Control/Pump: SPRINKLER CONTROL ROOM ACCESSIBLE THRU FRONT ROOM OF COMMERCIAL SPACE, THRU RESTROOM ON THE RIGHT NEAR FIRE ALARM PANEL.  
~~No pump - Simple residential system.~~
- Fire Department Connection(s) "FDC" per code: Y / N Y How many 1  
Location(s) Front of bldg - AT FRONT RIGHT CORNER (AD) OF BLDG ON RIGHT WALL (D).
- Number of Standpipe Risers None Hose Connection Location Not Applicable
- Fire Hydrant(s) Location: In the Street WEST CORNER OF INTERSECTION OF BARONNE ST. AND TERPSICHORE ST.
- Fire Department Apparatus Access: Public Street / Private Fire Lane  
Street Name(s) Public Street- 1609 and 1613 Baronne Street
- General Compliance with the current Fire Prevention Code -Comply
- Other: AS PER SFM CAUTIONARY CODES AR.20.016704 & WAIVER AP.20.016715.

A permit is required for the installation, alteration, or addition to any fire protective signaling, detection, or suppression system(s). A permit application fee shall be submitted to this office prior to installation of any system(s). Please contact this office if you have any questions.

Respectfully,

*[Signature]*  
Plans Examiner