



John Bel Edwards
GOVERNOR

Office of State Fire Marshal

8181 Independence Blvd. Baton Rouge, LA 70806
(225) 925-4911 (800) 256-5452 Fax (225) 925-4241



H. "Butch" Browning
FIRE MARSHAL

Cautionary Codes

Project Number:	AR-21-018137
Project Name:	HARRAH'S CASINO & HOTEL - PODIUM PKG

The items listed below are comments for informational purposes or identified requirements that will be verified upon final inspection by this office. These requirements need not be addressed back to the reviewer, however should be addressed prior to construction and inspection scheduling. Failure to comply with or otherwise address these items may affect final occupancy and use of the structure.

1	<p>Scope of Work: This review applies to the DEMO, CLEANING, REPAIR AND IMPROVEMENTS to the EXTERIOR of the Harrah's Casino.</p> <p>Extent of work for this review also includes the REFURBISHMENT of the Entries at the Poydras, S. Peters and Canal street entrances.</p> <p>LSC: ASSEMBLY IBC: GROUP A-2</p>
2	<p>A REVIEW FOR COMPLIANCE WITH THE FIRE PROTECTION AND EGRESS REQUIREMENTS OF CHAPTERS 9 AND 10 OF THE INTERNATIONAL BUILDING CODE IS INCLUDED IN THIS REVIEW. Review for compliance with all other requirements of the LOUISIANA STATE UNIFORM CONSTRUCTION CODE, in accordance with Act 12 of the 2005 First Extraordinary Session of the Louisiana Legislature, IS NOT INCLUDED IN THIS REVIEW. Contact the building official of the applicable political subdivision to coordinate compliance with these requirements. LRS 40:1730.23 mandates the enforcement of building codes by municipalities and parishes in Louisiana, as described by LRS 40:1730.28.</p>
3	<p>101:4.6.10.1 Buildings or portions of buildings shall be permitted to be occupied during construction, repair, alterations, or additions only if all means of egress and all fire protection features are in place and continuously maintained for the portion(s) occupied.</p>
4	<p>IBC 1010.1.10 Doors in a required means of egress serving any ASSEMBLY area having an occupant load of 50 or more persons shall NOT be equipped with a latch or lock other than panic hardware or fire exit hardware.</p>
5	<p>101:8.3.5 Penetrations through rated construction shall be sealed by approved firestop systems or devices tested in accordance with ASTM E-814 or ANSI/UL 1479.</p> <p>a. Notify the District Office identified at the end of the attached PROJECT DATA REPORT for inspection of all completed fire and/or smoke barrier walls before any construction is installed that would conceal such construction and prevent a proper inspection. Access to randomly selected areas may be required by the inspector at time of final inspection if this notification is not given.</p> <p>b. Provide detailed instructive cut sheets of the fire penetration sealing system used to the inspector at time of inspection. Random selective sampling by the contractor will be observed by the inspector.</p>