


NEW ORLEANS FIRE DEPARTMENT
317 DECATUR ST., N.O. LA 70130



FIRE PREVENTION DIVISION
(504) 658-4770 FAX (504) 565-7951

REVIEWED N.O.F.D FIRE PREVENTION PLAN EXAMINER  DATE <u>3/25/22</u>
--

Date: 3/25/2022

Contact Person: Robert Baddour Project Name: 2223 Magazine St.

Address: 1075 Race St. Project Address: 2223 Magazine St.
New Orleans, LA 70130 New Orleans, LA 70130

Dear Sir/Madam:


Please be advised that the above referenced plans and specifications have been reviewed by the Fire Prevention Division. Plans are approved as indicated below:

- Location of Fire Command Station (if High-rise building) N/A
- Location of Fire Alarm Control Panel: In Copy Room
Remote Annunciator Panel: Hall 1 front entry
- Sprinkler Control Pump: N/A
- Location of Fire Department Connection(s) "FDC" per code Y/N How many 1
Location(s): Front right side of bldg..
- Number of Standpipe Risers: 0 Hose Connection Locations: Floor/Intermediate Landing
(Circle One)
- Fire Hydrant Location: Corner of Magazine & Jackson
- Fire Department Apparatus Access: Public Street/Private Fire Lane
Street Name(s): Magazine St.
- General Compliance with the current Fire Prevention Code
Work shall be performed in accordance with the provisions of AR-21-021127 Review and
- Other: Cautionary Codes

A permit is required for the installation, alteration, or addition to any fire protective signaling, detection, or suppression systems. A permit application and a fee schedule shall be obtained and submitted to this office prior to installation of any systems.

Please contact this office if you have any questions.

Sincerely,


Plan Examiner