




General Notes Revision/Issue Date KENNON C. CROCKETT, P.E 2924 SABINE ST. NEW DRLEANS, LA 70114 504-305-8550 8940 JEANETTE ST NEW DRLEANS, LA 70118 A1.1

Scale 1/8"= 1








THESE PLANS ARE THE SOLE PROPERTY OF K CROCKETT DESIGNS, LLC. ALL RIGHTS ARE RESERVED BY THE ENGINEER AND USE OF THESE PLANS FOR CONSTRUCTION PURPOSES, OR FOR REPRODUCTION THEREOF, IN WHOLE OR IN PART, IS FORBIDDEN WITHOUT COMPENSATION TO AND WRITTEN PERMISSION FROM THE ENGINEER

EVERY EFFORT HAS BEEN MADE TO INSURE THE ACCURACY AND CORRECTNESS OF THESE DRAWINGS. IT IS THE REPSONSIBILITY OF THE CONTRACTOR TO RE-CHECK THESE PLANS FOR ACCURACY OR ERROR. ANY DISCREPANCY SHOULD BE REPORTED FOR CORRECTION PRIOR TO BEGINNING CONSTRUCTION.

K CROCKETT DESIGNS, LLC

http://www.kcrockettdesigns.com NEW ORLEANS, LA 70114



	دی	20/1				٥	/1	<u>_4</u>	RECEPTACLES (BEDRUUM)		
LES	25	20/1	<u>-</u>		1)	20.	/1	26	SPARE		
	27	20/1				20.	/1	28	DISHWASHER		
	29	20/1	\Box		(-	20.	/1	30	WASHER		
		BOLS									
	م ا										
	0—00 CHANDELIER				L	→ SINGLE POLE LIGHT SWITCH 3 WAY LIGHT SWITCH					
	3,0										
							D DINMER LIGHT SWITCH				
	CEILING FAN					C= 110 VOLT RECEPTACLE 220 VOLT RECEPTACLE WEATHER PROOF RECEPTACLE RECEPTACLE WITH GROUND FAULT INTERRUPT CABLE PHONE					
	CELLING FAM / LIGHT SECURITY LIGHTS WITH MOTION AND LIGHT SCHOOLS										
	MOTION AND LIGHT SENSOR			`	<)	MC	OTION SENSOR				
		CEILING MOUNTED LIGHT FIXTURE				TURE) D0	OR BELL		
	WALL MOUNTED LIGHT FATURE					LIGHT / VENT					
	WALL MOUNTED EIGHT PIXTORE					10	LIGHT/ VENT / HEAT				
	\sim				L						
			RECESSED CAN LIGHT						- NO. 12 COPPER WIRE INSULATED MIN. (GROUND).		
	DIRECTIONAL RECESSED CAN					_		LOW VOLTAGE WIRE (AS INDICATED)			
			EO HUNAL	. REUES	SED CAN		$\overline{}$		4 BULB FLOURESCENT FIXTURE		

FP

SIZE NO.

50/2 | 16 | RANGE

60/2 20 A/C UNIT

20/1 2 RECEPTACLES (LIV,DIN.)

20/1 4 RECEPTACLES (FAMILY)

20/1 6 RECEPTACLES (BATH)

20/1 8 RECEPTACLES (BATH)

20/1 10 RECEPTACLES (BATH)

20/1 12 RECEPTACLES (BEDROOM)

20/1 14 RECEPTACLES (BEDROOM)

20/1 24 RECEPTACLES (BEDROOM)

TYPICAL PANEL

ND. SIZE

1 20/1

5 20/1

7 20/1 _

9 20/1 -

13 30/2

17 20/2

11 20/1 ____

| 21 | 20/1 |-^-

23 20/1 ____

TYPE I HAD

LIGHTING (BATH, HALL, BDRM) 3 20/1

LIGHTING (KIT,LIV,DIN.)

HEAT, VENT, LIGHT (BATH)

HEAT, VENT, LIGHT (BATH)

HEAT, VENT, LIGHT (BATH)

SMOKE DETECTORS

CLOTHES DRYER

120/240V, 1PH, 3W, 200A MAINS, M.L.D., S/N, RECESSED, 10.000 A.I.C.

RUS

SERVICE (A/C PANEL SM SINGLE STATION SMOKE DETECTOR (120V) WITH BATTERY BACKUP (ALL SMOKE DETECTORS SHALL BE ON THE SAME CIRCUIT WITH AN ARC FAULT CARBON MONOXIDE DETECTOR **3** (S) **3**

1. ALL VORK SHALL BE DONE IN STRICT CONFORMITY WITH THE LATEST EDITION OF NATIONAL ELECTRIC CODE, CITY BUILDING CODE AND ALL OTHER INSPECTION DEPARTMENTS HAVING JURISDICTION AND FROM WHOM PROPER CERTIFICATES OF APPROVAL SHALL BE FURNISHED.

2. CONTRACTOR SHALL GUARANTEE ALL MATERIAL AND VORKMANSHIP FOR A PERIOD OF DNE YEAR FROM THE DATE OF ACCEPTANCE OF THE VORK. UPON COMPLETION CONTRACTOR SHALL FURNISH DWNER WITH A SET OF AS-BUILT DRAWINGS.

ALL MATERIALS FUNISHED SHALL BE NEW AND SHALL BE UL LISTED. 4. ELECTRICAL CONTRACTOR SHALL VISIT THE JOB SITE PRIOR TO BID AND FAMILIARIZE HIMSELF VITHALL EXISTING CONDITIONS AND INCLUDE IN HIS BID AMOUNT, AS REQUIRED, TO PERFORM HIS VORK VITHIN THE LIMITAITON OF EXISTING SITE.

5. ALL METAL RACEWAYS, BOXES FITTINGS, SUPPORTS AND SUPPORT HARDWARE SHALL BE OF MATERIALS SUTABLE FOR THE ENVIRONMENT IN WHICH THEY ARE TO BE INSTALLED.

6. ALL WIRING SHALL BE RUN CONCEALED WHEREVER POSSIBLE. ANY EXPOSE WIRING SHALL BE RUN IN CONDUIT.

7. ALL INTERIOR VIRING SHALL BE NON-METALIC SHEATHED COPPER CABLE. PRIVIDE GROMMETS AT ALL PEMETRATOINS AND APPROVED CABLE CLAMPS TI SECURE TO METAL-VADIO STUDS. ALL EXPISED COMDUIT SHALL BE RIGID GALVANIZED STEEL ALL CONDUIT RUN UNDERGROUND SHALL BE PVC. SERVIC CONDUITS RUN UNDERGROUND FOR ALL UTILITIES SHALL BE PVC ENCASED IN CONCRETE.

BHOMERUNS SHOWN ARE DIAGRAMMATIC UNLY, CONTRACTOR TO DETERMINE THE BEST ROUTING AND PROVIDE NECESSARY SUPPORT IN ACCORDANCE WITH APPLICABLE PROVISIONS OF N.E.O. ARTICLE SOO "WIRING METHODS".

9. ELECTRICAL CONTRACTOR TO CODRRDINATE WITH THE MECHANICAL EQUPMENT SUPPLIER FOR EXACT REQUIREMENTS PRIOR TO ROUGH-INS.

10. CONDUCTOR INSULATION SHALL BE THVN, COPPER TYPE, MOISTURE AND HEAT-RESISTANT THERMO-PLASTIC 75 DEG C. TEMP. RATED, EXCEPT WHERE NOTED.

11. ALL ELECTRICAL ROUGH-INS SHOWN ON THIS PLAN SHALL INCLUDE AN INSULATED COPPER GROUNDING CONDUCTOR CONTAINED VITHIN THE SAME CODUIT AS THE CIRCUIT CONDUCTORS. THE INSULATED EQUIPMENT GROUNDING CONDUCTOR SHALL BE PROPERLY TERMINATED ON DIE END AT THE EQUIPMENT GROUND BUSS IN THE CORRESPONDING CIRCUIT BREAKER PANEL, AND ON THE DTHER END AT THE GROUNDING CONTACT OF A GROUNDING RECEPTACLE OR TO AN EQUIPMENT CABINET, AS APPLICABLE.

12. ALL EXPOSED NON-CURRENT CARRYING METALLIC PARTS OF ELECTRICAL EQUIPMENT, RACEVAY SYSTEM, AND THE NEUTRAL CONDUCTOR OF THE VIRING SYSTEM SHALL BE GROUNDED. THE GROUND CONNECTRION SHALL BE MADE A 1EH MAIN SERVICE EQUIPMENT.

14. THIS CONTRACTOR, BEFORE INSTALLING ANY OF THE VORK, SHALL SEE THAT IT DOES NOT INTERFERE WITH CLEARANCES REQUIRED FOR FINISHED CHUMS, HUND CELLINGS, PILASTER, PARTITIONS, VALL, ETC. AS SHOWN IN THE ARCHITECTURAL DRAVINGS AND DETAILS. IF ANY WORK IS SO INSTALLED AND IT LATER DEVELOPS THAT SUCH DETAILS OR DESIGN CANNOT BE FOLLED THIS CONTRACTOR AT HIS DIVE REPRINES SHALL MAKE SUCH CHANGES IN THE VORK AS DIRECTED BY THE ARCHITECT OR ENGINEER, AS VELL AS TO PERMITTHE INSTALLATION OF THE ARCHITECTURAL VORK SHOWN ON THE PLANS AND DETAILS.

15. ALL DISCONNECT SWITCHES SHALL BE HEAVY DUTY UNLESS DITHERWISE NOTED. ALL EXTERIOR DISCONNECT SWITCHES SHALL BE RATED NEMA-3R UNLESS DITHERVISE NOTED.

16. MAKE TEST IN CONNECTION WITH PROPER PERFORMANCE OF ALL ELECTRICAL SYSTEMS AS DESCRIBED IN THESE DRAWINGS AND SPECIFICATIONS.

17. ALL TEST SHALL BE MADE IN ACCORDANCE WITH THE LATEST STANDARD OF THE IEEE AND THE NEC.

18. ALL VIRING SHALL BE TESTED FOR PERFORMANCE, GROUNDING, AND INSULATION RESISTANCE. "MEGGER" TYPE INSTRUCHENT SHALL BE USED. CIRCUIT CONTINUITY AND DEPRATION TESTS ON ALL EQUIPMENT FURNISHED AND/OR CONNECTED BY THE ELECTRICAL CONTRACTOR SHALL BE MADE BY HIS AFTER SUCH EQUIPMENT HAS BEEN INSTALLED.

19. THE TESTS LISTED ABOVE SHALL BE MADE IN THE PRESENCE OF THE BULLDING ARCHITECT DR HIS REPRESENTATIVE. THE CONTRACTOR SHALL NOTIFY THE DVNER AND THE ARCHITECT AT LEAST TVENTY-FOUR HOURS IN ADVANCE OF THE TEST. THE CONTRACTOR SHALL PROVIDE ALL TESTING EQUIPMENT AND ALL CONSTS SHALL BE BORN BY HIM. VETTEN REPORTS SHALL BE MADE OF ALL TESTS, ALL FAULTS SHALL BE CORRECTED IMMEDIATELY.

20. PROVIDE TYPEWRITTEN DIRECTORY FOR EACH PANEL BOARD INDICATING EACH CIRCUIT AS WIRED AT COMPLETION OF JOB.

21. REFER TO ENTERGY SERICE INSTALLATIONSTANDARDS A-1-347, SHEETS 1 AND 2 OF 3 FOR POWER CO. REQUIRMENTS.

22. WORK INCLUDED PROVIDE EQUIPMENT, CONDUIT BOXES AND VIRING FOR TELEPHONE AND CABLE TV SYSTEMS AS SPECIFIED HEREIN AND AS INDICATE ON THE DRAVINGS. ALL EQUIPMENT SHALL BE SUITABLE FOR DEPRATION NOMINAL 120VOLT 60 HZ, SINGLE PHASE ELECTRIC POUVER SUPPLY, LICCATION OF THE VARIOUS COMPONENTS OF EACH SYSTEM SHALL BE INDICATED ON THE DRAVINGS, UNLESS OTHERVISE SPECIFIED HEREIN AFTER. CONDUCTORS UNLESS OTHERVISES SPECIFIED HEREIN AFTER. CONDUCTORS UNLESS OTHERVISES SPECIFIED AVERSY AND CABLES FOR EACH COMMUNICATION SYSTEM SHALL BE OF THE TYPES AND SIZES RECOMMENDED BY THE MANIFACTHER OF THE SYSTEM INVOLVED. BY THE MANUFACTURER OF THE SYSTEM INVOLVED.

23. TELEPHONE SYSTEMS PROVIDE CONDUITS, VIRING, DUTLET BOXES, DEVICES, AND TERNINAL BOARD FOR THE TELEPHONE SYSTEM AS INDICATED ON THE BRAVINGS. TELEPHONE DUTLETS SHALL BE IN DIR IN VALLS OR CASEVURK. STANDARD DUTLET BOX, WITH TELEPHONE PLATE ID MATCH VIRIN DEVICE PLATES. DUTLET COVERS TO BE AS SPECIFIED BY ARCHITECT OR ENGINEER.

24. SMDKE DETECTORS SHALL BE 120 VOLT UNSVITCHED SELF CONTAINED PHOTID-ELECTRIC VITH INTEGRAL AUDIBLE ALERT MOUNTED NG CLOSER THAN 6' TD VALL AND NG CLOSER THAN 3' TD ANY AIR REGISTER AND 1' FROM ANY LIGHT FIXTURE. FOR SPECIFIED DISABLED DVELLING UNIT FOR HEARING/VISUALLY DISABLED PROVIDE SNOKE DETECTROS VITH A STROBE. STOBE SHALL BE 110 OR 177 CANELA AND A MAXIMUM OF 16' FROM THE PILLOW. VIRE SMOKE DETECTORS SO THAT WHEN DNE GOES INTO ALARM ALL SMOKE DETECTORS GO INTO ALARM.

25. DOOR BELL! PROVIDE DOOR BELL WITH FLASHING LIGHT ON HEARING AND VISUALLY DISABLED DVELLING.

26. INSTALLTION OF SPECIAL SYSTEMS: ALL CABLING WILL BE INSTALLED INCOMPANIES AND INSTALLATION DRAVINGS, AND STATE AND LOCAL CODES HAVING JURISTICITION.

27. FIELD TESTS: FOLLOWING COMPLETE INSTALLTION, PERFORM ALL DEPARTIONS SPECIFIED IN PRESENCE OF DWNER AND ENGINEER OR ENGINEER REPRESENTITIVE.

28. TV CABLE SYSTEM: THE CONTRACTOR SHALL FURNISH ALL MATERIALS, LABOR, AND PRE-VIRING FOR CABLE TELEVISION SIGNAL DISTRIBUTION SYSTEM.



General Notes

KENNON C. CROCKETT, P. 2924 SABINE ST. NEW DRLEANS, LA 70114 504-305-8550

8940 IFANETTE ST NEW DRLEANS, LA 70118

A1.7 3/11/20 Scale 1/8"= 1


THESE PLANS ARE THE SOLE PROPERTY OF K CROCKETT DESIGNS, LLC. ALL RIGHTS ARE RESERVED BY THE ENGINEER AND USE OF THESE PLANS FOR CONSTRUCTION PURPOSES, OR FOR REPRODUCTION THEREOF, IN WHOLE OR IN PART, IS FORBIDDEN WITHOUT COMPENSATION TO AND WRITTEN PERMISSION FROM THE ENGINEER

EVERY EFFORT HAS BEEN MADE TO INSURE THE ACCURACY AND CORRECTNESS OF THESE DRAWINGS. IT IS THE REPSONSIBILITY OF THE CONTRACTOR TO RE-CHECK THESE PLANS FOR ACCURACY OR ERROR. ANY DISCREPANCY SHOULD BE REPORTED FOR CORRECTION PRIOR TO BEGINNING CONSTRUCTION.



K CROCKETT DESIGNS, LLC

http://www.kcrockettdesigns.com NEW ORLEANS, LA 70114



	23	20/1			<u> </u>	21	J/1	24	Н	KECELIACTEZ (RETKUTM)			
23	25	20/1	<u> </u>		(-	20	0/1	26	<u>.</u>	SPARE			
	27	20/1				20	0/1	28	3	DISHWASHER			
	29	20/1			<u>`</u>	20	0/1	30	ı	WASHER			
	_												
					LEC	TRIC	CAL SYMBOLS						
	١.	യ്ക്				-							
	°	CHANDELIER							— SINGLE POLE LIGHT SWITCH 3 WAY LIGHT SWITCH				
	15				-	D DIMMER LIGHT SWITCH							
	Ι,	CEILING FAN						110 VOLT RECEPTACLE					
									220 VOLT RECEPTACLE				
		Ι (7							WEATHER PROOF RECEPTACLE				
		CEILING FAN / LIGHT						RECEPTACLE WITH GROUND FAULT INTERRUPT CABLE					
		U							IONI				
	<	SECURITY LIGHTS WITH MOTION AND LIGHT SENSOR											
									мот	ION SENSOR			
		CEILING MOUNTED LIGHT FIXTURE)	000	R BELL			
		WALL MOUNTED LIGHT FIXTURE						8					
	.							<u> </u>					
		У				_	~ਨ	χ <u> </u>		IT/ VENT / HEAT			
		RECESSED CAN LIGHT											
			OCOOCD (WALL CLOSE		_				 NO. 12 COPPER WIRE INSULATED MIN. (GROUND). 			
						-	_			LOW VOLTAGE WIRE (AS INDICATED)			
	_	727							_	4 BULB FLOURESCENT FIXTURE			
			ATHER P	ROOF RE		CAN							
	_	<u></u>				_	E	FP	=				
	- 1	\ _ /				- 1							

TYPICAL PANEL

ND. SIZE

1 20/1

5 20/1

13 30/2

17 20/2

15

7 20/1 _

9 20/1 -

11 20/1 ____

| 21 | 20/1 |-^-

23 20/1 ____

 \mathbf{Z}

TYPE I HAD

LIGHTING (BATH,HALL,BDRM) 3 20/1

LIGHTING (KIT,LIV,DIN.)

HEAT, VENT, LIGHT (BATH)

HEAT, VENT, LIGHT (BATH)

HEAT, VENT, LIGHT (BATH)

SMOKE DETECTORS

CLOTHES DRYER

120/240V, 1PH, 3W, 200A MAINS, M.L.D., S/N, RECESSED, 10.000 A.I.C.

RUS

SIZE NO.

50/2 | 16 | RANGE

60/2 20 A/C UNIT

20/1 2 RECEPTACLES (LIV,DIN.)

20/1 4 RECEPTACLES (FAMILY)

20/1 6 RECEPTACLES (BATH)

20/1 8 RECEPTACLES (BATH)

20/1 10 RECEPTACLES (BATH)

20/1 12 RECEPTACLES (BEDROOM)

20/1 14 RECEPTACLES (BEDROOM)

20/1 24 RECEPTACLES (BEDROOM)

SM SINGLE STATION SMOKE DETECTOR (120V) WITH BATTERY BACKUP (ALL SMOKE DETECTORS SHALL BE ON THE SAME CIRCUIT WITH AN ARC FAULT

CARBON MONOXIDE DETECTOR

1. ALL VORK SHALL BE DONE IN STRICT CONFORMITY WITH THE LATEST EDITION OF NATIONAL ELECTRIC CODE, CITY BUILDING CODE AND ALL OTHER INSPECTION DEPARTMENTS HAVING JURISDICTION AND FROM WHOM PROPER CERTIFICATES OF APPROVAL SHALL BE FURNISHED.

2. CONTRACTOR SHALL GUARANTEE ALL MATERIAL AND WORKMANSHIP FOR A PERIOD OF DNE YEAR FROM THE DATE OF ACCEPTANCE OF THE WORK. UPON COMPLETION CONTRACTOR SHALL FURNISH OWNER WITH A SET OF AS-BUILT DRAVINGS.

ALL MATERIALS FUNISHED SHALL BE NEW AND SHALL BE UL LISTED. 4. ELECTRICAL CONTRACTOR SHALL VISIT THE JOB SITE PRIOR TO BID AND FAMILIARIZE HIMSELF VITHALL EXISTING CONDITIONS AND INCLUDE IN HIS BID AMOUNT, AS REQUIRED, TO PERFORM HIS VORK VITHIN THE LIMITAITON OF EXISTING SITE.

5. ALL METAL RACEWAYS, BOXES FITTINGS, SUPPORTS AND SUPPORT HARDWARE SHALL BE OF MATERIALS SUTABLE FOR THE ENVIRONMENT IN WHICH THEY ARE TO BE INSTALLED.

6. ALL WIRING SHALL BE RUN CONCEALED WHEREVER POSSIBLE. ANY EXPOSE WIRING SHALL BE RUN IN CONDUIT.

7. ALL INTERIDR VIRING SHALL BE NON-METALIC SHEATHED COPPER CABLE.
PRIVITIE GROMMETS AT ALL PENETRATIONS AND APPROVED CABLE CLAMPS TO
SECURE TO METAL-VOIDO STUDS. ALL EXPOSED CONDUIT SHALL BE RIGID
GALVANIZED STEEL ALL CONDUIT RUN UNDERGROUND SHALL BE PVC. SERVICE
CONDUITS RUN UNDERGROUND FOR ALL UTILITIES SHALL BE PVC ENCASED IN
CONCRETE.

8.HDMERUNS SHOWN ARE DIAGRAMMATIC DNLY. CONTRACTOR TO DETERMINE TH BEST ROUTING AND PROVIDE NECESSARY SUPPORT IN ACCORDANCE WITH APPLICABLE PROVISIONS OF NEC. ARTICLE 300 "WIRING METHODS".

9. ELECTRICAL CONTRACTOR TO COORRDINATE WITH THE MECHANICAL EQUPMENT SUPPLIER FOR EXACT REQUIREMENTS PRIOR TO ROUGH-INS.

10. CONDUCTOR INSULATION SHALL BE THVN, COPPER TYPE, MOISTURE AND HEAT-RESISTANT THERMO-PLASTIC 75 DEG C. TEMP. RATED, EXCEPT WHERE NOTED.

11. ALL ELECTRICAL ROUGH-INS SHOWN ON THIS PLAN SHALL INCLUDE AN INSULATED COPPER GROUNDING CONDUCTOR CONTAINED VITHIN THE SAME CODUIT AS THE CIRCUIT CONDUCTORS. THE INSULATED EQUIPMENT GROUNDING CONDUCTOR SHALL BE PROPERLY TERMINATED ON DIE END AT THE EQUIPMENT GROUND BUSS IN THE CORRESPONDING CIRCUIT BREAKER PANEL, AND ON THE DTHER END AT THE GROUNDING CONTACT OF A GROUNDING RECEPTACLE OR TO AN EQUIPMENT CABINET, AS APPLICABLE.

12. ALL EXPOSED NON-CURRENT CARRYING METALLIC PARTS OF ELECTRICAL EQUIPMENT, RACEVAY SYSTEM, AND THE NEUTRAL CONDUCTOR OF THE VIRING SYSTEM SHALL BE GROUNDED. THE GROUND CONNECTRION SHALL BE MADE A 1EH MAIN SERVICE EQUIPMENT.

14. THIS CONTRACTOR, BEFORE INSTALLING ANY OF THE VORK, SHALL SEE THAT IT DOES NOT INTERFERE WITH CLEARANCES REQUIRED FOR FINISHED COLUMNS, HUND CEILINGS, PILASTER, PARTITIONS, WALL, ETC. AS SHOWN IN THE ARCHITECTURAL BRAVINGS AND DETAILS. IF ANY WORK IS SO INSTALLED AND IT LATER DEVELOPS THAT SUCH DETAILS OR DESIGN CANNOT BE FOLLED HIS CONTRACTOR AT HIS DUM EXPENSE SHALL MAKE SUCH CHANGES IN THE WORK AS DIRECTED BY THE ARCHITECT OR ENGINEER, AS WELL AS TO PERMIT THE INSTALLATION OF THE ARCHITECTURAL WORK SHOWN ON THE PLANS AND DETAILS.

15. ALL DISCONNECT SWITCHES SHALL BE HEAVY DUTY UNLESS DITHERWISE NOTED. ALL EXTERIOR DISCONNECT SWITCHES SHALL BE RATED NEMA-3R UNLESS DITHERWISE NOTED.

16. MAKE TEST IN CONNECTION WITH PROPER PERFORMANCE OF ALL ELECTRICAL SYSTEMS AS DESCRIBED IN THESE DRAWINGS AND SPECIFICATIONS.

17. ALL TEST SHALL BE MADE IN ACCORDANCE WITH THE LATEST STANDARD OF THE IEEE AND THE NEC.

18. ALL VIRING SHALL BE TESTED FOR PERFORMANCE, GROUNDING, AND INSULATION RESISTANCE. "MEGGER" TYPE INSTRUCHENT SHALL BE USED. CIRCUIT CONTINUITY AND DEPRATION TESTS ON ALL EQUIPMENT FURNISHED AND/OR CONNECTED BY THE ELECTRICAL CONTRACTOR SHALL BE MADE BY HIS AFTER SUCH EQUIPMENT HAS BEEN INSTALLED.

19. THE TESTS LISTED ABOVE SHALL BE MADE IN THE PRESENCE OF THE BULLDING ARCHITECT DR HIS REPRESENTATIVE. THE CONTRACTOR SHALL NOTIFY THE DVNER AND THE ARCHITECT AT LEAST TVENTY-FOUR HOURS IN ADVANCE OF THE TEST. THE CONTRACTOR SHALL PROVIDE ALL TESTING EQUIPMENT AND ALL CONSTS SHALL BE BORN BY HIM. VETTEN REPORTS SHALL BE MADE OF ALL TESTS, ALL FAULTS SHALL BE CORRECTED IMMEDIATELY.

20. PROVIDE TYPEWRITTEN DIRECTORY FOR EACH PANEL BOARD INDICATING EACH CIRCUIT AS WIRED AT COMPLETION OF JOB.

21. REFER TO ENTERGY SERICE INSTALLATIONSTANDARDS A-1-347, SHEETS 1 AND 2 OF 3 FOR POWER CO. REQUIRMENTS.

22. VORK INCLUDED PROVIDE EQUIPMENT, CONDUIT BOXES AND VIRING FOR TELEPHONE AND CABLE TV SYSTEMS AS SPECIFIED HEREIN AND AS INDICATE! ON THE DRAVINGS, ALL EQUIPMENT SHALL BE SUTABLE FOR OPERATION ON NOMINAL 120 VOLT 60 HZ, SINGLE PHASE ELECTRIC POVER SUPPLY, LICATION OF THE VARIOUS COMPONENTS OF EACH SYSTEM SHALL BE INDICATED ON THE DRAVINGS, UNLESS DITHERVISE SPECIFIED HEREIN AFTER. CONDUCTORS UNLESS OTHERVISE SPECIFIED HEREIN AFTER. CONDUCTORS UNLESS OTHERVISE SPECIFIED WITHOUT AND ASSESSED FOR EACH COMMUNICATION SYSTEM SHALL BE OF THE TYPES AND SIZES RECOMMENDED BY THE MANIFACTURER OF THE SYSTEM INVOLVED. BY THE MANUFACTURER OF THE SYSTEM INVOLVED.

23. TELEPHONE SYSTEMS PROVIDE CONDUITS, WIRING, OUTLET BOXES, DEVICES, AND TERMINAL BOARD FOR THE TELEPHONE SYSTEM AS INDICATED IN THE DRAWINGS. TELEPHONE OUTLETS SHALL BE IN OR ON WALLS OR CASEVURK, STANDARD DUTLET BOX, WITH TELEPHONE PLATE TO MATCH WIRIN DEVICE PLATES. DUTLET COVERS TO BE AS SPECIFIED BY ARCHITECT OR ENGINEER.

24. SMDKE DETECTORS SHALL BE 120 VOLT UNSVITCHED SELF CONTAINED PHOTID-ELECTRIC VITH INTEGRAL AUDIBLE ALERT MOUNTED NG CLOSER THAN 6' TD VALL AND NG CLOSER THAN 3' TD ANY AIR REGISTER AND 1' FROM ANY LIGHT FIXTURE. FOR SPECIFIED DISABLED DVELLING UNIT FOR HEARING/VISUALLY DISABLED PROVIDE SNOKE DETECTROS VITH A STROBE. STOBE SHALL BE 110 OR 177 CANELA AND A MAXIMUM OF 16' FROM THE PILLOW. VIRE SMOKE DETECTORS SO THAT WHEN DNE GOES INTO ALARM ALL SMOKE DETECTORS GO INTO ALARM.

25. DOOR BELL: PROVIDE DOOR BELL WITH FLASHING LIGHT ON HEARING AND VISUALLY DISABLED DVELLING.

26. INSTALLTION OF SPECIAL SYSTEMS: ALL CABLING WILL BE INSTALLED INCOMPANIES AND INSTALLATION DRAVINGS, AND STATE AND LOCAL CODES HAVING JURISTICITION.

27. FIELD TESTS: FOLLOWING COMPLETE INSTALLTION, PERFORM ALL DECRATORS SPECIFIED IN PRESENCE OF DWNER AND ENGINEER OR ENGINEER REPRESENTITIVE. 28. TV CABLE SYSTEM: THE CONTRACTOR SHALL FURNISH ALL MATERIALS, LABOR, AND PRE-VIRING FOR CABLE TELEVISION SIGNAL DISTRIBUTION SYSTEM.

Revision/Issue Date


General Notes

KENNON C. CROCKETT, P. 2924 SABINE ST. NEW DRLEANS, LA 70114 504-305-8550


roject Name and Address


8940 IFANETTE ST NEW DRLEANS, LA 70118

A1.8 3/11/20 Scale 1/8"= 1



HVAC SYMBOLS





THESE PLANS ARE THE SOLE PROPERTY OF K CROCKETT DESIGNS, LLC. ALL RIGHTS ARE RESERVED BY THE ENGINEER AND USE OF THESE PLANS FOR CONSTRUCTION PURPOSES, OR FOR REPRODUCTION THEREOF, IN WHOLE OR IN PART, IS FORBIDDEN WITHOUT COMPENSATION TO AND WRITTEN PERMISSION FROM THE ENGINEER

EVERY EFFORT HAS BEEN MADE TO INSURE THE ACCURACY AND CORRECTNESS OF THESE DRAWINGS. IT IS THE REPSONSIBILITY OF THE CONTRACTOR TO RE-CHECK THESE PLANS FOR ACCURACY OR ERROR. ANY DISCREPANCY SHOULD BE REPORTED FOR CORRECTION PRIOR TO BEGINNING CONSTRUCTION.



K CROCKETT DESIGNS, LLC

http://www.kcrockettdesigns.com NEW ORLEANS, LA 70114

General Notes Date No. Revision/Issue


KENNON C. CROCKETT, P.E. 2924 SABINE ST. NEW DRLEANS, LA 70114 504-305-8550


Project Name and Ad

8940 JEANETTE ST NEW DRLEANS, LA 70118



HVAC SYMBOLS






THESE PLANS ARE THE SOLE PROPERTY OF K CROCKETT DESIGNS, LLC. ALL RIGHTS ARE RESERVED BY THE ENGINEER AND USE OF THESE PLANS FOR CONSTRUCTION PURPOSES, OR FOR REPRODUCTION THEREOF, IN WHOLE OR IN PART, IS FORBIDDEN WITHOUT COMPENSATION TO AND WRITTEN PERMISSION FROM THE ENGINEER


EVERY EFFORT HAS BEEN MADE TO INSURE THE ACCURACY AND CORRECTNESS OF THESE DRAWINGS. IT IS THE REPSONSIBILITY OF THE CONTRACTOR TO RE-CHECK THESE PLANS FOR ACCURACY OR ERROR. ANY DISCREPANCY SHOULD BE REPORTED FOR CORRECTION PRIOR TO BEGINNING CONSTRUCTION.



K CROCKETT DESIGNS, LLC

http://www.kcrockettdesigns.com NEW ORLEANS, LA 70114





1. MAKE CONCRETE BASE PAD 4" LARGER. E.W. ARDUND EQUIPMENT. 2. FOR UNIT SIZE AND WEIGHT

SEE PLAN AND SCHEDULE

CONCRETE PAD and DECK FOR COND. UNIT

THESE PLANS ARE THE SOLE PROPERTY OF K CROCKETT DESIGNS, LLC. ALL RIGHTS ARE RESERVED BY THE ENGINEER AND USE OF THESE PLANS FOR CONSTRUCTION PURPOSES, OR FOR REPRODUCTION THEREOF, IN WHOLE OR IN PART, IS FORBIDDEN WITHOUT COMPENSATION TO AND WRITTEN PERMISSION FROM THE ENGINEER

EVERY EFFORT HAS BEEN MADE TO INSURE THE ACCURACY AND CORRECTNESS OF THESE DRAWINGS. IT IS THE REPSONSIBILITY OF THE CONTRACTOR TO RE-CHECK THESE PLANS FOR ACCURACY OR ERROR. ANY DISCREPANCY SHOULD BE REPORTED FOR CORRECTION PRIOR TO BEGINNING CONSTRUCTION.


K CROCKETT DESIGNS, LLC

http://www.kcrockettdesigns.com NEW ORLEANS, LA 70114

DIFFUSER, REGISTER AND GRILLE SCHEDULE SUPPLY DIFFUSERS 4 **>** MANUF. & NECK FACE SIZE MODEL# SIZE MOUNT MATERIAL ACCESSORIES FINISH TYPE NOTES METALAIRE DR EQUAL 8X6 7-1/4 X 7-1/4 SURFACE METALAIRE OR EQUAL 10X10 11-1/4 X 11-1/4 SURFACE 0 METALAIRE OR EQUAL 10X10 11-1/4 X 11-1/4 SURFACE METALAIRE DR EQUAL 18X10 17-1/4 X 11-1/4 SURFACE METALAIRE DR EQUAL 18X10 17-1/4 X 11-1/4 SURFACE (METALAIRE DR EQUAL 20X10 21-1/4 X 13-1/4 SURFACE A $\begin{pmatrix} 1 \\ 10 \end{pmatrix}$ I. PROVIDE ROUND TO RECTANGLE COLLAR VHERE INDICATED. 2. NOTE VHEN INSTALLING GRILLE ROTATE SO THAT 'LING' DIMENSION HEIGHT AND BLADES ARE TOWARD FLOOR. VC - VOLUTE DOWN BVE - BAKED WHITE ENAMEL DD - DOUBLE DEFLECTOR BAR FAB - FIXED ANGLE BLADE EXHAUST FAN SCHEDULE MARK CFM STATIC IN VOLTS VATTS ACCESSORIES EF-1 100 0.125 120/1 LTG & 1 kW HEATER RECESSED, SWITCH LIGHT, HEAT & FAN EF-2 100 0.125 LTG & 1 kW HEATER RECESSED, SVITCH LIGHT, SHEARN & FAN SEE PRODUCT SPECS. BROWN E661 OR EQUAL * 550 CFM & 9.5 SONES IN BOOST MODE F-1 FURNACE SCHEDULE VOLTS VATTS ACCESSORIES 120/1 SPLIT SYSTEM AIR COOLED HEAT PUMP SCHEDULE D.A. MBH @ 95F HEAT ELEC COMPRESSOR FAN FAN LRA RLA ELEC HP PAYMENT. AC-1 2.5 120/1 800 0 13.0 24.7 15.0 5 54 12.0 1.1 1/4 -AC-2 2.5 120/1 800 0 13.0 24.7 15.0 5 54 12.0 1.1 1/4 -RANGE HODD: DUCTED 30' VIDE RANGE HODD; VHITE IN COLLOR, 2 SPEED MOTOR, 120v 2.5A; 75V LAMP; DISHWASHER SAFE ALUMINUM GREASE FILTER AND BUILT IN DRAIN. - BELMONT CAP -STORM COLLAR RUUE -- FLASHING CONE INCREASE FOR INSULATION). ►MIN. 1/4" GAP EXHAUST PIPE EXHAUST DUCT THROUGH ROOF DETAIL WHERE CEILING ACCESS IS NOT AVAILABLE FIT BALANCING DAMPER WITH STRING BRANCH DUCT TAKE OFF. ADJUSTMENT VIA DIFFUSER/ CUSHIDN HEAD INTERNALLY INSULATED 25MM THICK FIBERGLASS GRILLE REMOVABLE CORE ROOF OR WALL, AS APPROVED. WITH ROUND DUCT REDUCERS. METAL AND FLEX DUCT.

HVAC SYMBOLS





DIFFUSER/GRILLE & CUSHION HEAD DETAII

ALL PLUMBING AND HVAC SYSTEMS SHALL BE IN ACCORDANCE WITH THE 2012 IRC AS ADOPTED BY JEFFERSON

2. THE TYPE AND COLOR OF ALL PLUMBING FIXTURES SHALL BE SELECTED BY THE OWNER PRIOR TO SIGNING CONTRACT. THE CONTRACTOR SHALL SUBMIT CUT SHEET AND SAMPLES OF THE FIXTURES HE INTENDS TO INSTALL.

3. THE HVAC SYSTEMS SHALL BE INSTALLED BY A LICENSE PROFESSIONAL, AUTHORIZED TO PREFORM WORK IN JEFFERSON

4. THE MANUFACTURER'S WARRANTY SHALL BE SUBMITTED TO THE HOMEOWNER PRIOR TO CONTRACTOR RECIEVING FINAL

5. THE HVAC SYSTEM SHALL BE PROPERLY SIZED FOR THE AMOUNT LIVING SPACE. MINIMUM HVAC SYSTEM SIZE SHALL BE 2.5 TONS WITH APPROPRIATE AIR HANDLER.

HEATING / AIR CONDITIONING UNIT SHALL BE ATTIC TYPE FORED AIR ELECTRIC HEAT COMPLETE WITH COIL DRAIN PAN

7. THE HVAC SYSTEM RECOMMENDED TO BE 16 SEER.

INSULATE REFRIGERATION LINES AND RUN CONCEALED IN WALLS AND ATTIC (1/2" ARMAFLEX MIN.).

9. TRUNK DUCT SHALL BE FLEX MATERIAL. USE A MIN. OF 1'THICK STANDARD DUTY DUCT BOARD (DUCT SIZE IS NET,

10. PROVIDE FRESH AIR INTAKE THROUGH ROOF WITH DAMPER, APPROVED ALUMINUM CAP AND INSECT SCREEN.

11. TURNING VANE AT EACH BRANCH DUCT TAKE OFF.

12. PLACE A 125° FIRESTAT IN EACH RETURN AIR PLENUM.

13. VOLUME CONTROL DAMPER IN EACH TRUNK LINE AND

14. EACH RETURN AIR GRILLE IS TO HAVE UNIT FILTERS WITH GRILLE FRAME, LOCATE AS REQUIRED.

15. FOR EACH RESTROOM VENT A 4" EXHAUST DUCT THROUGH

16. DIFFUSERS TO BE AIR-MATE 190 OR EQUAL, SQUARE TYPE

17. CEILING DIFFUSERS NECK TO BE THE SAME AS SUPPLY DUCT. DIFFUSER TO HAVE OPPOSED BLADE DAMPER.

18. USE 2" MIN. EXTERIOR WRAP FIBERGLASS INSULATION ON

19. EXACT LOCATION / ORIENTATION OF A/C UNIT AND RETURN AIR TO BE DETERMINED BY MECHANICAL CONTRACTOR AT TIME OF CONSTRUCTION.

NTS 20. THE HOT WATER HEATER SHALL BE 40 GALLONS CAPACITY.

Revision/Issue Date KENNON C. CROCKETT, P.E NEW ORLEANS, LA 70114 504-305-8550

General Notes

A1.5a 1/8"= 1

