



John Bel Edwards
GOVERNOR

Office of State Fire Marshal

8181 Independence Blvd. Baton Rouge, LA 70806
(225) 925-4911 (800) 256-5452 Fax (225) 925-4241



Daniel H. Wallis
FIRE MARSHAL

PLAN REVIEW REPORT

CHARLES MCKAY
2526 PACKENHAM ROAD
VIOLET LA 70092

Project Number: **FA-22-010681**
Review Type: **Fire Alarm System**
Status: **Released**
Date Completed: **7/14/2022**
Code Edition: **2015**

In accordance with L.R.S. 40:1574 et seq., satisfactory compliance with the requirements of the laws, rules, regulations and codes of the state that are entrusted to the State Fire Marshal to uphold must be achieved before any work is performed. As such, a permit shall not be issued or construction or installation of the scope of work identified herein shall not commence until the Status of this review is "Released" and the requirements of other state and local entities have been satisfied.

Project Description: INSTALLATION OF ONE FIRE ALARM SYSTEM TO MONITOR THE SPRINKLER SYSTEM, SMOKE DETECTION AND HIGH CANDELA STROBE/520 HZ. HORN/STROBES IN ALL SLEEPING AREAS. SYSTEM WILL HAVE REMOTE MONITORING FOR PROPER NOTIFICATION OF ANY ALARMS, TROUBLES AND/OR SUPERVISORY SIGNALS.			
Project Name: DAVID AND MEGAN BUTLER		Address: 1233 ST. BERNARD AVE., NEW ORLEANS, LA 70116	
Funding Type: Private Project	Within City Limits? YES	Number of Stories: 2	High Rise Building: No
Occupancy Separation Type:	Total Occupancy Square Feet: 2304	Project on which Floor(s): 1, 2	Construction Type: III-B / III(200)
Additional Features (if applicable): Fire Alarm System			

Occupancy Type(s) and Square Feet		
Occupancy Type: Residential	Square Feet: 2304	Details: RESIDENTIAL BUILDING: GROUP R-3 (SMALL MISCELLANEOUS); NUMBER OF OCCUPANTS: 10

Fire Alarm	
Is this System required by Code or by an Equivalency to Code?	Required by Code
Is the system a new installation or a modification to an existing system?	N
System Type:	Remote Station

Device Type:	Number of Devices:
Heat Detector	1
Horn/Strobe	6
Smoke Detector (Include Duct Detectors)	5
Panel	1


Are plans being submitted by OSFM Licensed Qualifier?			Y
OSFM Firm License Number: F2218	OSFM Qualifier License Number: E284	Engineer License Number:	

Individuals Involved in this Project		
Name: CHARLES ALAN MCKAY	Role: Professional of Record - CIVIL ENGINEER (E-37185)	Address: 2526 PACKENHAM ROAD, VIOLET, LA 70092
DAVID BUTLER	Owner	1233 ST. BERNARD AVE., NEW ORLEANS, LA 70116
NESTOR HOUGHTON	Contractor	1901 INDUSTRIAL BLVD., HARVEY, LA 70058
RAYMOND JOSEPH DELAUNE	Additional Contact (INSTALLATION MANAGER)	1901 INDUSTRIAL BLVD., SUITE C, HARVEY, LA 70058

Changes that are inconsistent with the reviewed documents are not authorized unless reviewed by this office for compliance with adopted codes, rules and laws. The changes must be submitted to this office by the Professional of Record where required by law, otherwise by the Owner, for review prior to construction and inspection. Minor changes may be submitted as supplemental information amended to this assigned project number. Changes that alter the scope of work, or that otherwise will require another full review of the project, will require a complete resubmittal of the entire scope of work with application, revised plans, and applicable review fee.

This review shall in no way permit or authorize any omissions or deviations from the specific requirements of the adopted codes, rules and regulations of the state. Construction permits must be issued or installation must commence within 180 days from the date of the "Released" Status for this submittal.

Occupancy of the project will not be permitted until a satisfactory inspection of the completed construction has been made by this office. Please allow at least two (2) weeks advanced notice to schedule inspections.

Review Completed By	
Signature:	
Name: Brian Beadle	Badge No.: 650

Distribution List		
Name	Firm Name	Role
NEW ORLEANS CITY PERMITS		Permit Office