

# wingate

E N G I N E E R S

July 19, 2022

Deron Lee  
Building Plan Examiner  
Office of Business and External Services  
1300 Perdido, 7<sup>th</sup> Floor  
New Orleans, LA 70112

Subject: Permit 22-18439-RNVS Renovation (Structural)  
5022 Loyola Ave

Dear Mr. Lee

In reference to your comments regarding the permit mentioned above, the foundation plan was designed as a pier-beam system to match existing residential foundation and to avoid differential settlement

Please feel free to contact me for any questions or concerns.

Thank You,  
Wingate Engineers, LLC.



Joshua Torregano, P.E.  
President

