

								MODULE	<u> </u>								7 [
	REF.	F. QTY. MAKE AND MODEL				PMAX	PTC	ISC	IMP	VOC VMP TEMP. COEFF. OF VOC				FUSE RATING			
Р	M1-20	20 20 CANADIAN SOLAR CS1U-410MS				410W	383W	9.70A	9.23A	53.6	V 44.5\	/	-0.155V/°C (-0.29%/°C)			20A	IJ L
	INVERTERS																
REF. C	QTY. MAKE AND MODEL		AC VOLTAGE	GROUNE)	RATED POWER		MAX OL	JTPUT CI	UT CURRENT MAX		(INPUT CURRENT MAX INPUT VC		AGE	WEIGHTED EFFICIENCY		
I1	1 1 SOLAR EDGE SE7600H-US [240V] 240V		240V	NOT SOLIDLY GR	OUNDED	7,600w			25.0A		16.5A			99.0%			
OPTIMIZERS																	
R	EF.	QTY.	MODEL	RATED	INPUT POWER	MAX OUTPUT CURRENT				MAX INPUT ISC		MAX DC VOLTAGE		WEIGHTED EFFICIENCY			
PC)1-20	20 SOLAR EDGE P505 505W		15A				11.0A		83	83V		98.8%				
DISCONNECTS OCPDS																	
REF.	QTY.	7. MAKE AND MODEL RATED CURF			RATED CURRE	ENT	MAX RATED VOLTAGE				REF. C		RATED CURRENT			MAX VOLTAGE	1
SW1	1 SQUARE D D223NRB OR EQUIV. 100A			100A			240VAC			F1-2	2	2 35A		35A 0VAC			

SYSTEM SUMMARY									
	STRING 1	STRING 2							
DC SOURCE CIRCUIT CURRENT	15A	15A							
NUMBER OF OPTIMIZERS	7	7							
NOMINAL STRING VOLTAGE	380V	380V							
ARRAY OPERATING CURRENT	7.6A	7.6A							
ARRAY STC POWER	5,7	5,740W							
ARRAY PTC POWER	5,3	5,361W							
MAX AC CURRENT	2	25A							
MAX AC POWER OUTPUT	6,0	6,000W							
DEDATED AS DOMED SUITBUT		E 043M/							

NOTES

SOLAR EDGE SYSTEM MEETS REQUIREMENTS FOR PHOTOVOLTAIC RAPID SHUTDOWN SYSTEM (PVRSS), AS PER NEC 690.12(B).

MATING CONNECTORS SHALL COMPLY WITH NEC 690.33.

THE SPECIFIED OPTIMIZER CAN BE SUBSTITUTED WITH A P505. THIS OPTIMIZER HAS AN INPUT VOLTAGE WINDOW WIDE ENOUGH TO ACCOMMODATE THE OUTPUT VOLTAGE RANGE OF THE MODULE AT THE SPECIFIED OF IMIZER CAN BE SUBSTITUTED WITH A F303. THIS OF IMIZER HAS AN INPUT VOLTAGE WINDOW WIDE ENOUGH TO ACCOMMODATE THE OUTPUT VOLTAGE RANGE OF THE MODULE AT THE DESIGN TEMPERATURES, HAS A MAX INPUT CURRENT RATING THAT IS ABOVE THE MAX OUTPUT OF THE MODULE, AND A MAX POWER INPUT THAT IS ABOVE THE RATED POWER OUTPUT OF THE MODULE.

DC PV CONDUCTORS ARE NOT SOLIDLY-GROUNDED. NO DC PV CONDUCTOR SHALL BE WHITE- OR GRAY-COLORED

ALL METAL ENCLOSURES, RACEWAYS, CABLES AND EXPOSED NONCURRENT-CARRYING METAL PARTS OF EQUIPMENT SHALL BE GROUNDED TO EARTH AS REQUIRED BY NEC 250.4(A) AND PART III OF ARTICLE 250 AND EQUIPMENT GROUNDING CONDUCTORS SHALL BE SIZED ACCORDING TO NEC 690.45. THE GROUNDING ELECTRODE SYSTEM SHALL ADHERE TO NEC 690.47(A) AND NEC 250.169. THE DC GROUNDING ELECTRODE SHALL BE SIZED ACCORDING TO NEC 250.166 AND INSTALLED IN COMPLIANCE WITH NEC 250.64.

MAX DC VOLTAGE OF ARRAY FIXED BY THE INVERTER AT 380V REGARDLESS OF TEMPERATURE. THE MAX DC VOLTAGE OF THE MODULE AT -15°C IS 59.8V (-15°C - 25°C) X -0.155V/C + 53.6V = 59.8V).

POINT-OF-CONNECTION IS ON THE SUPPLY SIDE OF SERVICE DISCONNECT. INSIDE PANEL BOARD ENCLOSURE USING UNUSED TERMINALS. TERMINALS THAT ARE SUITABLE FOR DOLIBLE LUGGING, OR USING OTHER LOCALLY APPROVED METHODS AND HARDWARE, IN COMPLIANCE WITH NEC 705.12(A), THE PANELBOARD SHALL HAVE SUFFICIENT SPACE TO ALLOW FOR ANY TAP HARDWARE AS REQUIRED

PV SYSTEM DISCONNECT SHALL BE A VISIBLE KNIFE-BLADE TYPE DISCONNECT THAT IS ACCESSIBLE AND LOCKABLE BY THE UTILITY. THE DISCONNECT SHALL BE LOCATED WITHIN 10 FT OF UTILITY METER. DISCONNECT SHALL BE GROUPED IN ACCORDANCE WITH NEC 230.72.

CONDUCTOR AND CONDUIT SCHEDULE W/ELECTRICAL CALCULATIONS												
CONDUCTOR	CONDUIT / CABLE	CURRENT-CARRYING CONDUCTORS IN CONDUIT / CABLE	OCPD	EGC	TEMP. CORR. FACTOR	FILL FACTOR	CONT. CURRENT	MAX. CURRENT (125%)	BASE AMP.	DERATED AMP.	TERM. TEMP. RATING	AMP. @ TERM. TEMP. RATING
10 AWG PV WIRE, COPPER	FREE AIR	N/A	N/A	6 AWG BARE, COPPER	0.76 (55°C)	1.0	15A	18.75A	55A	41.8A	75°C	50A
10 AWG THWN-2, COPPER	0.75" DIA. EMT	4	N/A	10 AWG THWN-2, COPPER	0.96 (33°C)	0.8	15A	18.75A	40A	30.72A	90°C	40A
8 AWG THWN-2, COPPER	0.75" DIA. EMT	2	35A	10 AWG THWN-2, COPPER	0.96 (33°C)	1.0	25A	31.25A	55A	52.8A	75°C	50A
6 AWG THWN-2, COPPER	0.75" DIA. EMT	2	35A	10 AWG THWN-2, COPPER	0.96 (33°C)	1.0	25A	31.25A	75A	72A	75°C	65A

GENERAL ELECTRICAL NOTES

UTILITY HAS 24-HR UNRESTRICTED ACCESS TO ALL PHOTOVOLTAIC SYSTEM COMPONENTS LOCATED AT THE SERVICE ENTRANCE.

CONDUCTORS EXPOSED TO SUNLIGHT SHALL BE LISTED AS SUNLIGHT RESISTANT PER NEC

ARTICLE 300.6 (C) (1) AND ARTICLE 310.10 (D).

CONDUCTORS EXPOSED TO WET LOCATIONS SHALL BE SUITABLE FOR USE IN WET LOCATIONS PER NEC ARTICLE 310.10 (C).

GROUNDING NOTES

ALL EQUIPMENT SHALL BE PROPERLY GROUNDED PER THE REQUIREMENTS OF NEC ARTICLES 250 & 690 PV MODULES SHALL BE GROUNDED

TO MOUNTING RAILS USING MODULE LUGS OR RACKING INTEGRATED gROUNDING CLAMPS AS ALLOWED BY LOCAL JURISDICTION. ALL OTHER EXPOSED METAL PARTS SHALL BE GROUNDED USING UL-LISTED LAY-IN

LUGS. INSTALLER SHALL CONFIRM THAT MOUNTING SYSTEM HAS BEEN **EVALUATED FOR COMPLIANCE WITH** UL 2703 "GROUNDING AND BONDING" WHEN USED WITH PROPOSED PV

IF THE EXISTING MAIN SERVICE PANEL DOES NOT HAVE A VERIFIABLE GROUNDING

MODULE.

4 ELECTRODE. IT IS THE CONTRACTOR'S RESPONSIBILITY TO INSTALL A SUPPLEMENTAL GROUNDING ELECTRODE. AC SYSTEM GROUNDING ELECTRODE CONDUCTOR (GEC)

5 SHALL BE A MINIMUM SIZE #8AWG WHEN INSULATED, #6AWG IF BARE WIRE.

EQUIPMENT GROUNDING CONDUCTORS SHALL BE SIZED ACCORDING TO NEC ARTICLE 690.45.

6 AND BE A MINIMUM OF #10AWG WHEN NOT EXPOSED TO DAMAGE, AND #6AWG SHALL BE USED WHEN **EXPOSED TO DAMAGE** GROUNDING AND BONDING CONDUCTORS, IF INSULATED, SHALL

7 BE COLOR CODED GREEN, OR MARKED GREEN IF #4AWG OR LARGER

SINGLE-LINE DIAGRAM SCALE: NTS



STEM

SX

POWER

 Δ

OLA

ഗ

GRID-TII

8.20 SE CANADIAN SOLAR 410

SINGLE-LINE DIAGRAM

PROJECT ID: 164609 DATE: 11/30/21

CREATED BY: W.K.

CHECKED BY:

REVISIONS

