

DEPARTMENT OF SAFETY AND PERMITS
CITY OF NEW ORLEANS

LATOYA CANTRELL
MAYOR

TAMMIE JACKSON
DIRECTOR

Friday, August 12, 2022

PERMIT NO: 22-22168-RNVN
ADDRESS: 2618 Bristol Pl
NATURE OF WORK: Renovation (Non-Structural)

Dear Daryl S. Evans Sr.:

Investigation of the above referenced plans and specifications indicate the following:

Division	Category	Comment
Plan Review		PLAN REVIEW: This project has been reviewed by Jessika Thibodeaux. For email and digital document correspondence, please send to JESSIKA.THIBODEAUX@NOLA.GOV
Plan Review		PLAN REVIEW: Please provide sketch that provides the areas provide a travel distance, means of egress of doors and windows, indicate room use, smoke alarms windows, and door access.
Permit Intake	Floor Plan	Permit Intake - Please identify the use of all of the rooms. Please provide a detailed sketch that outlines the floor plan of the structure to be renovated with each room labeled and indications of what work is to be done. Please also include the address of the property being worked on.

A re-review fee will be assessed for any revised drawings submitted to this office as per the International Code adopted and amended by the City of New Orleans. All revised drawings submitted shall properly reflect the changes from the original drawings.

1300 PERDIDO STREET SUITE 7E06 NEW ORLEANS, LOUISIANA 70112
PHONE 504-658-7115 FAX 504-658-7212



Please be advised that this review does not include signs and/or plumbing work shown on the drawings. Any questions about plumbing shall be directed to Sewerage and Water Board, 625 St. Joseph Street, New Orleans, La. 70165, (504) 585-2160.

Be advised also, that all alternative building products, components, methods and materials require current Evaluation report from ICC Evaluation Services, Inc., (ICC-ES) as evidence that such products and systems meet code requirements.

The ICC-ES Evaluation report shall be submitted for review if you plan to use such alternative products or methods.

A response to the code requirements indicated above must be submitted **by the architect or engineer** to the Plan Processing Division to facilitate completion of the review process, approval of the plans and issuance of the building permit. No improvements or construction is authorized until the building permit is issued.

If you have any questions regarding this Building Permit, Please feel free to contact this office at (504) 658-7115 [FAX 504-658-7210]. Your cooperation will be greatly appreciated.

Yours very truly,

cc: Building, Fire Prevention