

840 Tchoupitoulas St New Orleans, LA 70130 - Permit Application

sandy@waterproofingnola.com <sandy@waterproofingnola.com>

Mon 8/15/2022 1:12 PM

To: Warren E. Jones <Warren.Jones@nola.gov>

EMAIL FROM EXTERNAL SENDER: DO NOT click links, or open attachments, if sender is unknown, or the message seems suspicious in any way. DO NOT provide your user ID or password. If you believe that this is a phishing attempt, use the reporting tool in your Outlook to send this message to Security.

Good afternoon - thank you for your question - yes - we confirm compliance in the form of protection with an impact resistant covering in accordance with 2015 IBC, Section 1609.1.2 in the form of 7/16" plywood with anchors.

Let us know if you have any further questions.

Warm regards,

Sandy Beauchesne
Client Service & Operations Manager
Paramount Waterproofing Solutions
6221 S Claiborne Ave, #618
New Orleans, LA 70125

waterproofingnola.com

504.723.4112