

STEVEN J. FINEGAN ARCHITECT, LTD.

A PROFESSIONAL CORPORATION

123 South Pierce St.

New Orleans, LA 70119

PH: (504) 486-5744

stevefinegan@nocoxmail.com

August 9, 2022

To: New Orleans Department of Safety & Permits

Re: City Planning Commission Zoning Docket: 036/19; Ref. Code NWRZJB; Parking Lot Permit #21-08086-NEWC; Sidewalk Permit 21-08341-RSWR

Attn: Cynthia Cross

Dear Ms. Cross:

We have finally received CPC approval and have contracted with a general contractor to do the work on this project. The following is in response to the last review comments that we received dated April 26, 2021:

1. We have approval from Kevin Giroir of the DPW and Parks and Parkways – see attached sheet LS-1 with approval stamps from both agencies.
2. The guard booth is a prefabricated building – see attached sheet A2.2 for the elevations and details 9,10,11/A3.0 for the foundation. A flood vent shall be installed in the field by the general contractor.
3. My understanding is that the Conditional Use has been approved by the City Planning Commission but I do not have paperwork saying that it is. The CPC person that was handling the project was Joseph Colon and I understand that he is no longer with the agency.
4. See the attached signed construction contract between Durr Heavy Construction, LLC and St. Charles Holdings, LLC for \$994,689.00.

Thank you.

Sincerely,

Steve Finegan, AIA