

Dennis P. Murphy

From: Roberto Ocegüera <roberto@elementalarchitecture.com>
Sent: Wednesday, August 17, 2022 10:21 AM
To: Dennis P. Murphy
Cc: Favio Castán; Tracie Ashe
Subject: Re: Arrive Hotel - 600 Mazant_Signage Revisions

EMAIL FROM EXTERNAL SENDER: DO NOT click links, or open attachments, if sender is unknown, or the message seems suspicious in any way. DO NOT provide your user ID or password. If you believe that this is a phishing attempt, use the reporting tool in your Outlook to send this message to Security.

Hi Dennis,

Just following up on this. Please find written responses below to help clarify your questions.

1. Mounting: The new sign includes individual letters attached to a backing panel that then gets attached to the dropped ceiling fascia at the driveway. See example image below.



2. The letters are intended to be solid black letters with white backing panel. Letters are intended to be back lit.

3. Yes, these are 4" deep letters.

4. Exposed conduit note added as requested.

Please let us know if you have any other questions or comments.

Thanks,

Roberto

On Mon, Aug 15, 2022 at 2:05 PM Roberto Ocegüera <roberto@elementalarchitecture.com> wrote: