

STEVEN J. FINEGAN ARCHITECT, LTD.

A PROFESSIONAL CORPORATION

123 South Pierce St.

New Orleans, LA 70119

PH: (504) 486-5744

stevefinegan@nocoxmail.com

August 19, 2022

To: New Orleans Department of Safety & Permits

Re: Permit #21-24905-RNVS – 317 Chartres St.

Attn: Meghan Murphy

Dear Ms. Murphy:

The following is in response to the last review comments that we received on the above referenced project per your e-mail of 8/19/2022:

1. See the attached reflected ceiling plan for Unit 201 on sheet A9.0 showing the required smoke detectors.
2. All of the new windows in the project shall have 9/16" thk. impact-rated glass.

Thank you.

Sincerely,



Steve Finegan, AIA

