

**RE: Permit 22-24409-RNVS Renovation (Structural) at 2718-2720 St Philip St**

Matt Fox &lt;matt@ms-fox.com&gt;

Sun 8/28/2022 8:07 AM

To: Warren E. Jones &lt;Warren.Jones@nola.gov&gt;

**EMAIL FROM EXTERNAL SENDER: DO NOT click links, or open attachments, if sender is unknown, or the message seems suspicious in any way. DO NOT provide your user ID or password. If you believe that this is a phishing attempt, use the reporting tool in your Outlook to send this message to Security.**

Mr. Jones,

PLAN REVIEW GENERAL NOTE: The 2015 International Residential Code ("2015 IRC") applies to one and two-family dwellings not more than three stories above grade plane, and their accessory structures. Unless noted otherwise, all review comments and citations reference the 2015 IRC, including all relevant subsections.

**See note on cover sheet - bottom of middle section - all plans will meet IRC 2015 and city of New Orleans amendments as required**

PLAN REVIEW WIND SPEED: The City of New Orleans requires structures be designed for 130 mph basic wind speed. Please confirm.

**See note on sheet A10 - under structural notes section II.B - structural design based on wind loads of up to 150 mph**

PLAN REVIEW GLAZING: Provide wind-borne debris protection for exterior glazing in accordance with 2015 IRC, Sec. R301.2.1.2. Glazed opening protection shall meet the requirements of the Large Missile Test of ASTM E 1996 and ASTM E 1886. (Exception: Wood structural panels with a minimum thickness of 7/16" (11 mm) and a maximum span of 8 feet shall be permitted for opening protection in one- and two-story buildings. Panels shall be precut, predrilled, attached to the framing surrounding the opening and secured as per 2015 IRC, Sec. R301.2.1.2.) Please confirm.

**Wind Borne Debris protection shall be provided as required in Section R301.2.1.2.**

Permit Intake - Please submit the name and license number of the state approved contractor.

**Contractor's License number is 881698.**

Will send signed contract and riser diagram as I get that information from the contractor.

Thanks,

Matt

---

Matthew S. Fox | Fox Design | 710 Congress St. New Orleans, LA 70117 | [240.447.6208](tel:240.447.6208)

STATEMENT OF CONFIDENTIALITY:

The information contained in this electronic message and any attachments to this message are intended for the exclusive use of the addressee(s) and may contain confidential or privileged information. If you are not the intended recipient, or the person responsible for delivering the e-mail to the intended recipient, be advised you have received this message in error and that any use, dissemination, forwarding, printing, or copying is strictly prohibited. Please notify M. Fox Design immediately at either 240.447.6208 or [matt@ms-fox.com](mailto:matt@ms-fox.com) and destroy all copies of this message and any attachments.