



Composite of roof plan-view and array layout



Street View

4920 Chestnut St, New Orleans, LA 70115, USA

Peggy Pryor

9.62 kW PV System

4920 Chestnut St

New Orleans, LA 70115

## PROJECT DETAILS

### Scope of Work

9.62 kW Enphase Roof Mounted PV System with BBU

Interconnection: Partial Home on 125A 2P Breaker | 50A 2P

Solar Breaker on Gateway Busbar

60A Non-Fused Lockable Knifeblade Solar Disconnect

1 x Tesla Gateway 2 with Internal Generation Busbar

1 x Tesla Powerwall PLUS

9 x Tesla MCI

### Site Conditions

Roof Type: Shingle

Roof Height: 14'

Mounting Planes: 3

Roof Pitch: 30° (7/12)

Roof Azimuth: 93, 273°

Utility: **ENO**

### Design Details

Module: 26 x Silfab Solar SIL-370 BK

Inverter: 1 x Tesla Solar Inverter 7.6 [240V]

Inverter Limitations: 12/string

Racking: Unirac SM Standard

Attachment: Flashkit Pro Comp Mount

Maximum Attachment Spacing: 72"