

THOMAS M. SMITH P.E.  
Consulting Engineer  
6516 Boutall Street  
Metairie, Louisiana, 70003  
504-887-3882, 504-247-6294

September 13, 2022

5814 Louisville St.  
New Orleans, La 70124


To Whom It May Concern:

Regarding open comments on permit reference #K6P6JN at 5814 Louisville St in New Orleans, Louisiana:

- \*Garage construction will have flood vents and flood resistant materials.
- \*Windows installed in bathtub enclosures less than 60" from the floor will have safety glazing in accordance with section R308.4.5 of the IRC 2015 ed.
- \*Approved smoke detectors should be provided in each bedroom and outside of each bedroom as required by Sec. R314 IRC 2015 ed.
- \*Where toilet rooms and bathrooms are mechanically ventilated, the ventilation equipment shall be installed in accordance with Section 1507 of the IRC 2015 ed.

Signed,

*Thomas M. Smith*  
9/14/22



THOMAS M. SMITH  
License No. 21980  
PROFESSIONAL ENGINEER  
IN  
CIVIL ENGINEERING

Tom Smith