


HISTORIC DISTRICT LANDMARKS COMMISSION CERTIFICATE OF APPROPRIATENESS

WORK APPROVED:

1. Replace existing inverted "V" chimney caps with flat galvanized metal cap for water intrusion prevention.
2. All changes and additional work must be approved by the HDLC.
3. For final, please contact the HDLC inspector, Daniel Syal, at Daniel.Syal@nola.gov or call the mainline (504) 658-7051.



NOT VALID UNLESS POSTED ON SITE

By posting this notice, the owner of the property certifies that they understand all work described above, and acknowledge that they are legally responsible for ensuring that all work performed has been approved prior to execution and is completed in accordance with approvals obtained. *** For questions regarding this approval or to schedule a final inspection call the number below ***

THIS FORM MUST REMAIN POSTED UNTIL WORK IS CERTIFIED AS COMPLIANT BY HDLC STAFF

1300 Perdido Street, Room 7W03 • New Orleans • LA • 70112 • (504) 658-7040 • www.nola.gov/hdlc

SOLO EL TRABAJO DESCRITO ANTERIORMENTE PUEDE REALIZARSE LEGALMENTE EN ESTE EDIFICIO

921-923 Sixth St

22-27901-HDLC

9/14/2022

OWNER: MARY ELLEN W FLEURY

APPLICANT: MARY ELLEN W FLEURY

ISSUED BY: WENDY CARGILE