

Fwd: Question Regarding Your Permit Application 2662-2664 n galvez

Cam D <barbies.only2@gmail.com>

Mon 9/19/2022 12:22 PM

To: Warren E. Jones <Warren.Jones@nola.gov>

EMAIL FROM EXTERNAL SENDER: DO NOT click links, or open attachments, if sender is unknown, or the message seems suspicious in any way. DO NOT provide your user ID or password. If you believe that this is a phishing attempt, use the reporting tool in your Outlook to send this message to Security.

Confirming yes to both

----- Forwarded message -----

From: **Cam D** <barbies.only2@gmail.com>

Date: Fri, Sep 16, 2022, 3:45 PM

Subject: Re: Question Regarding Your Permit Application 2662-2664 n galvez

To: Warren E. Jones <Warren.Jones@nola.gov>

Yes winds are capable for 130 winds

Yes glazing confirmed an will be completed as such

On Fri, Sep 16, 2022, 3:18 PM Warren E. Jones <Warren.Jones@nola.gov> wrote:

Cam D,

Thanks for the info. Noted. However, I have two other review comments that I will need you to respond to, as follows:

WIND SPEED:*The City of New Orleans requires structures be designed for 130 mph basic wind speed. Please confirm.***GLAZING:***Provide wind-borne debris protection for exterior glazing in accordance with 2015 IRC, Sec. R301.2.1.2. Glazed opening protection shall meet the requirements of the Large Missile Test of ASTM E 1996 and ASTM E 1886. (Exception: Wood structural panels with a minimum*