

St. Raymond / St. Leo the Great_Question Regarding Your Permit Application

Tony Taffaro <tony@vergesrome.com>

Thu 9/22/2022 11:11 AM

To: Warren E. Jones <Warren.Jones@nola.gov>

Cc: Rick Fenner <rick@vergesrome.com>

EMAIL FROM EXTERNAL SENDER: DO NOT click links, or open attachments, if sender is unknown, or the message seems suspicious in any way. DO NOT provide your user ID or password. If you believe that this is a phishing attempt, use the reporting tool in your Outlook to send this message to Security.

Mr. Jones,

Good morning. Please be advised of the following in response to your questions pertaining to the referenced permit application.

1. A signed contract with the General Contractor will be submitted once the project has been bid.
2. PLAN REVIEW WIND SPEED: All roofs being completely removed and replaced as a part of this project WILL be designed to withstand a basic (nominal) wind speed 130 mph, Exposure B, in accordance with 2015 IBC, Section 1609.

Please advise of any further questions.

Thanks,

Anthony J. Taffaro, A.I.A.

VergesRome Architects, APAC

320 N. Carrollton Avenue

New Orleans, Louisiana 70119

504-488-7739

tony@vergesrome.com

www.vergesrome.com

From: VRA Permitting <permitting@vergesrome.com>

Sent: Thursday, September 22, 2022 10:22 AM

To: Tony Taffaro <tony@vergesrome.com>; Rick Fenner <rick@vergesrome.com>

Subject: FW: Question Regarding Your Permit Application