

**Fwd: 7531 PLUM ST. (22-27RNVS) new plans sheet showing the elevation**

Manoel Ferreira &lt;Brabolllc@hotmail.com&gt;

Thu 9/29/2022 11:29 AM

To: Warren E. Jones &lt;Warren.Jones@nola.gov&gt;; Jerome A. Landry &lt;jlandry@nola.gov&gt;

 1 attachments (283 KB)

2022.0822\_A3.0R.pdf;

**EMAIL FROM EXTERNAL SENDER: DO NOT click links, or open attachments, if sender is unknown, or the message seems suspicious in any way. DO NOT provide your user ID or password. If you believe that this is a phishing attempt, use the reporting tool in your Outlook to send this message to Security.**

Here is the new page what's show the elevation what's showing the benchmark certificate, Owner approved be riser to the benchmark...

---

**From:** Lacey Wotring <lacey.wotring@gmail.com>**Sent:** Thursday, September 29, 2022, 8:58 AM**To:** Manoel Ferreira <brabolllc@hotmail.com>**Subject:** 7531 PLUM ST. (22-27RNVS)

Manoel,

Please see attached revised exterior elevations noting the change in elevation to meet BFE requirements. In addition, please relay the following message to Warren:

***Wind-borne debris protection shall comply with 2015 IRC. Precut 1/2" structural plywood panels shall be stored on-site. Panels shall be precut, pre-drilled, attached to the framing surrounding the opening and secured to each opening per 2015 IRC, Sec. R301.2.1.2.)***

Lacey Wotring  
ARCHETYPE, LLC  
504.298.9088 (p)  
337.280.1089 (c)

[www.studio-archetype.com](http://www.studio-archetype.com)