

# HISTORIC DISTRICT LANDMARKS COMMISSION CERTIFICATE OF APPROPRIATENESS

## WORK APPROVED:

1. Remove and salvage existing barrel style ridge tiles for reinstallation. Reinstall all salvaged ridge tiles.
2. Remove existing shingle roof and install architectural grade asphalt/fiberglass roof shingles, as per attached asphalt shingle brands and colors, approved 9/30/2022.
3. Repair/replace plywood decking, sheathing, and felt paper, as needed. Overall pitch and height of roof to match existing.
4. Repair/replace wooden fascia, as needed, to match existing in profile, dimension, and material.
5. Install low-profile roof vents, as needed, low-profile roof vents must be located at least 10'-0" back from the front wall of the building (not the front of the roof) at least 1'-0" down from the roof ridge. SUBMIT PRODUCT SPECIFICATIONS FOR ANY VENT LARGER THAN 4" IN DIAMETER FOR APPROVAL BEFORE PURCHASE OR INSTALLATION. Wind turbines and ridge vents are not approved at this building.
6. All repair/replace shall match existing in material, exposure, dimension, size, operation, configuration, and type.
7. All changes and additional exterior work must be approved by the HDLC.
8. Contact the HDLC at (504)658-7051 or contact HDLC inspector Alex Nassar at [anassar@nola.gov](mailto:anassar@nola.gov) for final inspection.

## NOT VALID UNLESS POSTED ON SITE

By posting this notice, the owner of the property certifies that they understand all work described above, and acknowledge that they are legally responsible for ensuring that all work performed has been approved prior to execution and is completed in accordance with approvals obtained. \*\*\* For questions regarding this approval or to schedule a final inspection call the number below \*\*\*

**THIS FORM MUST REMAIN POSTED UNTIL WORK IS CERTIFIED AS COMPLIANT BY HDLC STAFF**

1300 Perdido Street, Room 7W03 • New Orleans • LA • 70112 • (504) 658-7040 • [www.nola.gov/hdlc](http://www.nola.gov/hdlc)

SOLO EL TRABAJO DESCRITO ANTERIORMENTE PUEDE REALIZARSE LEGALMENTE EN ESTE EDIFICIO

22-29625-HDLC

1204 Barracks St

9/30/2022

OWNER: DONA L LIEF

APPLICANT: DONA L LIEF

ISSUED BY: YVETTE TYLER