

Re: 2YU14L

Seamus McGuire <seamus@cicadateam.com>

Tue 10/11/2022 9:31 AM

To: Warren E. Jones <Warren.Jones@nola.gov>

Cc: Todd W. Breckman <twbreckman@nola.gov>

EMAIL FROM EXTERNAL SENDER: DO NOT click links, or open attachments, if sender is unknown, or the message seems suspicious in any way. DO NOT provide your user ID or password. If you believe that this is a phishing attempt, use the reporting tool in your Outlook to send this message to Security.

Pinging you on this.

In addition DHH has been uploaded and confirmed.

Seamus McGuire, LEED AP BD+C

PARTNER

504.559.3103

www.cicada.xyz



On Mon, Oct 10, 2022 at 10:25 AM Seamus McGuire <seamus@cicadateam.com> wrote:

Warren,

With regards to 4206 Magazine Street, I have the following responses to your comments:

1. The rear canopy structure has been designed designed to withstand a basic (nominal) wind speed 130 mph, Exposure B, in accordance with 2015 IBC, Section 1609.
2. Fire Marshal Review has been uploaded to the portal and is approved.

Seamus McGuire, LEED AP BD+C

PARTNER

504.559.3103

www.cicada.xyz

