



Composite of roof plan-view and array layout



Street View

2444 Lapeyrouse St, New Orleans, LA 70119, USA

Yanti Turang

9.62 kW PV System

2444 Lapeyrouse St

New Orleans, LA 70119

PROJECT DETAILS

Scope of Work

9.62 kW Enphase Roof Mounted PV System with BBU

Interconnection: Partial Home on 125A 2P Breaker | 50A 2P

Solar Breaker on Gateway Busbar

60A Non-Fused Lockable Knifeblade Solar Disconnect

1 x Tesla Gateway 2 with Internal Generation Busbar

1 x Tesla Powerwall **PLUS**

9 x Tesla MCI RSD

1 x 16 Circuit Back Up

Site Conditions

Roof Type: Shingle

Roof Height: 15'

Mounting Planes: 1

Roof Pitch: 33° (8/12)

Roof Azimuth: 128°

Utility: **ENO**

Design Details

Module: 26 x Silfab Solar SIL-370 HC

Inverter: 1 x Tesla Solar Inverter 7.6 [240V]

Inverter Limitations: 11/string

Racking: Unirac SM Standard

Attachment: Flashkit Pro Comp Mount

Maximum Attachment Spacing: 72"

