



John Bel Edwards
GOVERNOR

Office of State Fire Marshal

8181 Independence Blvd. Baton Rouge, LA 70806
(225) 925-4911 (800) 256-5452 Fax (225) 925-4241

Cautionary Codes



Daniel H. Wallis
FIRE MARSHAL

Project Number:	AR-22-018683
Project Name:	BIZOU WINES

The items listed below are comments for informational purposes or identified requirements that will be verified upon final inspection by this office. These requirements need not be addressed back to the reviewer, however should be addressed prior to construction and inspection scheduling. Failure to comply with or otherwise address these items may affect final occupancy and use of the structure.

1	Scope of Work: This review applies to the installation of solar panels on the roof of 2 story 22,088 sf BUSINESS occupancy building.
2	101:4.6.10.1 Buildings or portions of buildings shall be permitted to be occupied during construction, repair, alterations, or additions only if all means of egress and all fire protection features are in place and continuously maintained for the portion(s) occupied.
3	This review applies to new work indicated in the drawings and does not apply to existing non-conforming conditions.