


- ◆ SHEET NOTES:**

  1. REFER TO SHEET 120-P-112E FOR CONTINUATION.
  2. REFER TO SHEET 120-P-132E FOR CONTINUATION.
  3. AVOID ROUTING NEW WASTE PIPING WITHIN ELECTRICAL ROOM BELOW.
  4. CONNECT 1/2" HWR TO HW THRU BALL VALVE AND CIRCUIT SETTER.
  5. CW/HW DOWN IN WALL, AND ROUTE HEADER WITHIN CHASE.

**CONSULTANT:** **msa**  
ENGINEERING CONSULTANTS  
**IMEG**  
370 East Windmill Lane, Suite 100  
Las Vegas, NV 89123  
T. (702) 896-1100  
msa-ec.com  
121106




BULLETIN 120-03  
10/12/2022



ISSUE	6/06/2022	
JOB	V21009	
DRAWN	Author	
SCALE	1/4" = 1'-0"	
REVISIONS		
01	7/15/2022	BULLETIN 120-01
03	10/12/2022	BULLETIN 120-03

120-P-420

20-P-420 NTS



120-P-420



REVISÉD ENTIRE SHEET