

HISTORIC DISTRICT LANDMARKS COMMISSION CERTIFICATE OF APPROPRIATENESS

WORK APPROVED:

1. Remove ALL roof-mounted solar panel racks, junction boxes and conduit installed on building without a CofA and install new visually prominent roof-mounted solar panels as per attached updated panel layout diagram and scope of work documents, approved 11/1/2022 and as per CMM approval with proviso at 9/7/2022 meeting.
2. All junction boxes and conduit should be minimized and must be installed in a manner that is not visible from all surrounding public rights of way. Junction boxes, if necessary, should be located below panels.
3. Commission approval proviso includes exterior conduit supply line for solar panels. Conduit must be carefully and discretely installed behind existing gutter and should run down building wall at existing rear downspout in a manner that minimizes its visibility from the street.
4. Panels must be installed in a continuous, rectangular arrangement on a black, low-profile, low-contrast racking system a minimum of 10'-0" from the front building wall (not including the porch or roof overhang), 1'-0" from all roof ridges and 1'-0" from all roof eaves. Rails shall not extend more than 0'-3" past panels. Exposed conduit and junction boxes are not permitted where visible from the public right of way.
5. Changes and/or variations in the panel layout diagram are not approved. All changes and/or variations in panel layout must be reviewed and approved by the HDLC prior to commencement of that work.
6. **ALL CHANGES OR ADDITIONAL WORK MUST BE APPROVED BY THE HDLC.**
7. Please contact the HDLC at (504)658-7051 or HDLC Building Inspector Alex Nassar at anassar@nola.gov for a final inspection once all work under this permit has been completed.

NOT VALID UNLESS POSTED ON SITE

By posting this notice, the owner of the property certifies that they understand all work described above, and acknowledge that they are legally responsible for ensuring that all work performed has been approved prior to execution and is completed in accordance with approvals obtained. *** For questions regarding this approval or to schedule a final inspection call the number below ***

THIS FORM MUST REMAIN POSTED UNTIL WORK IS CERTIFIED AS COMPLIANT BY HDLC STAFF

1300 Perdido Street, Room 7W03 • New Orleans • LA • 70112 • (504) 658-7040 • www.nola.gov/hdlc

SOLO EL TRABAJO DESCRITO ANTERIORMENTE PUEDE REALIZARSE LEGALMENTE EN ESTE EDIFICIO

22-13481-HDLC

5500 Dauphine St

11/1/2022

OWNER: CHIH K SUNG

APPLICANT: ASHLEY SHULER

ISSUED BY: DENNIS MURPHY