

HISTORIC DISTRICT LANDMARKS COMMISSION CERTIFICATE OF APPROPRIATENESS

WORK APPROVED:

1. Remove and salvage existing English-V tiles at ridge and barrel style ridge tiles on eaves for reinstallation. Reinstall all salvaged ridge tiles.
2. Remove existing shingle roof and install architectural grade asphalt/fiberglass roof shingles, as per attached asphalt shingle brands and colors, approved 11/10/2022.
3. Low-profile roof vents must be located at least 10'-0" back from the front wall of the building (not the front of the roof) at least 1'-0" down from the roof ridge. Submit product specifications for any vent larger than 4" in diameter for approval before purchase or installation.
4. Remove and salvage existing ridge crest for reinstallation. Reinstall salvaged ridge crest.
5. Repair/replace plywood decking, sheathing, and felt paper, as needed. Overall pitch and height of roof to match existing.
6. All repair/replace shall match existing in material, exposure, dimension, size, operation, configuration, and type, unless otherwise specified.
7. All changes and additional work must be approved by the HDLC.
8. For final, please contact the HDLC inspector, Alex Nassar, at anassar@nola.gov or call the mainline (504) 658-7051.

NOT VALID UNLESS POSTED ON SITE

By posting this notice, the owner of the property certifies that they understand all work described above, and acknowledge that they are legally responsible for ensuring that all work performed has been approved prior to execution and is completed in accordance with approvals obtained. *** For questions regarding this approval or to schedule a final inspection call the number below ***

THIS FORM MUST REMAIN POSTED UNTIL WORK IS CERTIFIED AS COMPLIANT BY HDLC STAFF

1300 Perdido Street, Room 7W03 • New Orleans • LA • 70112 • (504) 658-7040 • www.nola.gov/hdlc

SOLO EL TRABAJO DESCRITO ANTERIORMENTE PUEDE REALIZARSE LEGALMENTE EN ESTE EDIFICIO

908 Congress St

22-33852-HDLC

11/10/2022

OWNER: JOSEPH B CRUTHIRDS

APPLICANT: BRIAN J. MACKEL
ROOFING, LLC

ISSUED BY: KRISTA GUZZO