


HISTORIC DISTRICT LANDMARKS COMMISSION CERTIFICATE OF APPROPRIATENESS

WORK APPROVED:

1. Install metal sign, as shown on attached drawing, approved 11/18/2022. Sign must meet the standards set forth by the City of New Orleans Comprehensive Zoning Ordinance.
2. All changes and additional exterior work must be approved by the HDLC.
3. Contact the HDLC at (504)658-7051 or contact HDLC inspector Daniel Syal at daniel.syal@nola.gov for final inspection.



NOT VALID UNLESS POSTED ON SITE

By posting this notice, the owner of the property certifies that they understand all work described above, and acknowledge that they are legally responsible for ensuring that all work performed has been approved prior to execution and is completed in accordance with approvals obtained. *** For questions regarding this approval or to schedule a final inspection call the number below ***

THIS FORM MUST REMAIN POSTED UNTIL WORK IS CERTIFIED AS COMPLIANT BY HDLC STAFF

1300 Perdido Street, Room 7W03 • New Orleans • LA • 70112 • (504) 658-7040 • www.nola.gov/hdlc

SOLO EL TRABAJO DESCRITO ANTERIORMENTE PUEDE REALIZARSE LEGALMENTE EN ESTE EDIFICIO

735 St Joseph St

22-33415-HDLC

11/18/2022

OWNER: 735-37 ST JOSEPH ST
LLC

APPLICANT: DEANNA SILLIKER

ISSUED BY: YVETTE TYLER

Pour House-St Joseph



2527 HICKORY AVE. METAIRIE, LA 70003
 OFFICE: 504-737-7446 FAX: 504-737-3299
 TOLL FREE: 1-888-737-7446
 VISIT OUR WEB SITE: WWW.SIGNWORX.NET



BUILDING LINEAR: 24' SIGN SQ FT = 10.33 ft² PER SIDE

SIGNAGE SPECS:

- SUSPENDED SIGN
- OVERALL TOP SIGN SIZE: 36" x 36"
- OVERALL BOTTOM RIDER SIGN SIZE: 8" X 24"
- QTY:(1), DOUBLE SIDED
- .080 ROUTED ALUMINUM FACES
- DPRINT VINYL GRAPHICS
- SIGN INSTALLS SUSPENDED FROM BALCONY
- NON ILLUMINATED

USE EXISTING CHAINS

SIDE



ST. JOSEPH

CLIENT:

Pour House-District

ADDRESS:

735 ST. JOSEPH STREET
 NEW ORLEANS, LA 70116

DATE: 11/2/22

JOB NUMBER:52642

DESIGNER: AT

SIGNAGE DETAILS:



THIS DRAWING IS THE PROPERTY OF SIGNWORX. ANY ALTERATIONS ARE PROHIBITED WITHOUT WRITTEN CONSENT OF SIGNWORX. THIS DRAWING HAS BEEN MADE AVAILABLE TO THE CLIENT TO ILLUSTRATE DESIGN OR PRODUCTION DETAILS AND ARE NOT TO BE DISTRIBUTED FOR BID WITHOUT THE WRITTEN CONSENT OF SIGNWORX.

Dimensions and clearance must meet the standards set forth in the City of New Orleans Comprehensive Zoning Ordinance.

These plans and/or specifications have been prepared by or under my close supervision. I have researched the building and related construction codes of Orleans Parish and the Louisiana State Uniform Construction Code and to the best of my or my consultants knowledge and belief these drawings are in compliance therein. And that I am not administering the work.

Signage shall meet requirements of 2015 IBC Appendix H and related chapters. Signage shall meet requirements of ASCE 7.

140 mph wind load

