

Re: WAFFLE TIME

Ayman Alsayed <aymanxcell@gmail.com>

Mon 11/28/2022 2:46 PM

To: Gwen Shook <Gwen.Shook@la.gov>; Warren E. Jones <Warren.Jones@nola.gov>

Cc: Arion Moore <Arion.Moore@la.gov>; khalilalsayed45@gmail.com <khalilalsayed45@gmail.com>; Terrijon Hughes <Terrijon.Hughes@la.gov>; Zachary Doell <Zachary.Doell@la.gov>; Badr Daoud <badrdaoud.bd@gmail.com>

EMAIL FROM EXTERNAL SENDER: DO NOT click links, or open attachments, if sender is unknown, or the message seems suspicious in any way. DO NOT provide your user ID or password. If you believe that this is a phishing attempt, use the reporting tool in your Outlook to send this message to Security.

Hello Mrs. Shook

I added Mr. Warren Jones from The City Safety & Permits to this email.

Mr. Warren

We need your approval to waive the grease trap for the Waffle Time to get the DHH move forward. As we explained before we are a waffle and ice cream store we don't have any oil or fried usage.

Thank you all for your support

On Mon, Nov 28, 2022 at 10:17 AM Gwen Shook <Gwen.Shook@la.gov> wrote:

Mr. Alayed,

Thank you for submitting your information and pictures. Have you received a grease trap waiver from the city Safety & Permits and/or New Orleans Sewerage & Water Board departments?

The attached form is the city sanitation department check list stating a grease trap contract is not applicable.

Gwendolyn Shook, RS. M. Ed.

Sanitarian 5

Orleans Parish Sanitarian Services

935 Gravier Street, Suite 1420

New Orleans, LA 70112

Phone:504-568-7970

Email: gwen.shook@la.gov

INSPECTION REPORTS CAN BE FOUND AT

<http://la.healthinspections.us/stateoflouisiana/>

Don't forget to check out food safety information on DHH's www.eatsafe.la.gov website!

From: Ayman Alsayed <aymanxcell@gmail.com>

Sent: Sunday, November 27, 2022 3:26 PM

To: Arion Moore <Arion.Moore@la.gov>

Cc: khalilalsayed45@gmail.com; Gwen Shook <Gwen.Shook@LA.GOV>; Terrijon Hughes <Terrijon.Hughes@la.gov>; Zachary Doell <Zachary.Doell@LA.GOV>; Badr Daoud <badrdaoud.bd@gmail.com>; Ayman Alsayed <aymanxcell@gmail.com>

Subject: Re: WAFFLE TIME

EXTERNAL EMAIL: Please do not click on links or attachments unless you know the content is safe.

Hello Mrs. Arion

I hope you are doing well.

Finally we did all the following as requested, please check the answers and the attached. feel free to contact us if you have any questions

Please see attached examples of the three compartment sink and air gap that are required. **Done please check the attached picture**

Since there is no existing grease trap or grease interceptor installed in your establishment contact the **City of New Orleans Permit Department** at 504-658-7114 for sizing requirements. **Please check the attached letter**

For the restroom please be sure to have an open front toilet seat, a cover trash bin, a tight fitting self-closing door. **Done please check the attached picture**

Please be sure a single compartment hand sink is accessible to all prep areas and dish washing areas. **Done Please check the attached**

A mop sink is also required. If you have a hose connected, please be sure a backflow prevention device is installed (see above attachment). **Done Please check the attached**

Please be sure all coolers and freezers have thermometers. **Done Please check the attached**

Thank you

On Tue, Nov 15, 2022 at 11:21 AM Arion Moore <Arion.Moore@la.gov> wrote:

Good Morning Mr. Alsayed,

Nice speaking with you this morning.

Please review these items that show what is required for the establishment.

Please see attached examples of the three compartment sink and air gap that are required.

Since there is no existing grease trap or grease interceptor installed in your establishment contact the **City of New Orleans Permit Department** at 504-658-7114 for sizing requirements.

For the restroom please be sure to have an open front toilet seat, a cover trash bin, a tight fitting self-closing door.

Please be sure a single compartment hand sink is accessible to all prep areas and dish washing areas.

A mop sink is also required. If you have a hose connected, please be sure a backflow prevention device is installed (see above attachment).

Please be sure all coolers and freezers have thermometers.

If you have any more questions , please let me know.

Best,

Mrs. Arion D. Moore, BS, R.S.

Orleans Parish Sanitarian Services

Sanitarian 3

935 Gravier St.

14th Floor, Suite 1420

New Orleans, LA 70112

Phone: (504) 568-7970

Email: arion.moore@La.Gov

--

Thank you

Ayman Sayed

X-Cell Communications

Authorized dealer for Metro By [T.Mobile](#)

Regional Manager

Alabama - Mississippi- Kansas

3325 Lorna Road Suite 101 Hoover , AL 35216

205.757.1667

--

Thank you

Ayman Sayed

X-Cell Communications

Authorized dealer for Metro By T.Mobile

Regional Manager

Alabama - Mississippi- Kansas

3325 Lorna Road Suite 101 Hoover , AL 35216

205.757.1667