



John Bel Edwards
GOVERNOR

Office of State Fire Marshal

8181 Independence Blvd. Baton Rouge, LA 70806
(225) 925-4911 (800) 256-5452 Fax (225) 925-4241

Cautionary Codes



Daniel H. Wallis
FIRE MARSHAL

Project Number:	AR-22-021995
Project Name:	WAFFLE TIME

The items listed below are comments for informational purposes or identified requirements that will be verified upon final inspection by this office. These requirements need not be addressed back to the reviewer, however should be addressed prior to construction and inspection scheduling. Failure to comply with or otherwise address these items may affect final occupancy and use of the structure.

1	<p>Scope of Work: This review applies only to the change of ownership/tenancy at this facility. No change of occupancy classification and no substantial alteration to the existing building is affecting the exits, stairs, seating arrangement, fire protection, or other details of construction as identified in the submittal (R.S. 40:1574) .</p> <p>~ Resubmit for full review if a change of occupancy classification is intended, or if alterations affecting life safety and/or building protection are proposed.</p> <p>~ RS 40:1563 The state inspector shall verify existing conditions and issue a report citing non-conforming conditions at the time of final inspection, if applicable. (ALL EXISTING CONDITIONS - NO NEW WORK IS PROPOSED TO AFFECT FIRE PROTECTION OR LIFE SAFETY).</p>
2	<p>LRS 40:1574 Submit chemical fire suppression system shop drawings ON-LINE at https://lasfm.louisiana.gov/. Such work shall not commence until shop drawings have been found to be in compliance with applicable codes by this office. LINK the "AR" (architectural project) submittal, or reference it in the PROJECT NAME. (Systems include hoods, halon, wet or dry chemical systems, etc.)</p>
3	<p>NFPA 10:6.2.1.2 Provide portable fire extinguishers within the following travel distances; rectilinear route measure: Travel distance to a fire extinguisher shall not exceed 30 feet for Class K fires (cooking appliances). See NFPA 10:6.6.</p>