

December 13, 2022

Mr. Warren E. Jones
Building Plan Review
1300 Perdido St. Room 7E06
New Orleans, LA 70112

Re: 718 Valmont Street
New Orleans, LA 70115
Permit No.: 22-32175-RNVS

Dear Mr. Jones,

In response to your review of the plans for Permit Number 22-32175-RNVS, the following should fulfill the requirements necessary for permit release:

Parks and Parkways Tree Review:

1. There are no city trees adjacent to the address and no city trees will be affected by the addition.

Plan Review:

2. All plans conform to the 2015 IRC, including all relevant subsections.
3. The renovation conforms to the HDLC demolition guidelines and does not need further review by HDLC. Dennis Murphy has confirmed this via email.
4. Per IRC 2015, Section R301.2.1.2, all new glazing openings will have wood structural panels ½" plywood fabricated and left on site for protection against projectiles.
5. Attached is the plumber riser diagram.

Permit Intake:

6. Attached is the signed contract between Owner and Contractor for the work at 718 Valmont.

Sincerely,



Daniel Zangara, AIA

