

Pitt Street (rear)

Property Line



Upperline Street (side)

Property Line

Project Notes:

- Generator will be mounted on an owner-provided concrete slab
- Generator will be installed at or above base flood elevation
- Generator will be installed with minimum 5' overhead clearance
- Generator not with 5' of doors/windows
- All soffit vents will be permanently sealed within 10ft of either side of generator
- Generator 10ft from all air intakes and dryer vents
- Exhaust pointed away from habitable structures
- Installation meets all Manufacturer Installation Guidelines

Please sign below to accept the Generator Location as shown


X

GAS

ATS
Elec
Service



**38kW
Generac**



Robert Street (side)

Property Line

(front)

4920 St Charles Avenue

