


HISTORIC DISTRICT LANDMARKS COMMISSION CERTIFICATE OF APPROPRIATENESS

WORK APPROVED:

1. Install solar panels as per drawings, approved 12/16/2022. Solar panels to be a minimum of 12" from eaves and ridges, 10'-0" back from front wall of house, in a rectangular and contiguous arrangement, with a low-profile racking system, and black racking and frame with low contrast panels.
2. All changes and additional work must be approved by the HDLC.
3. For final, please contact the HDLC inspector, Daniel Syal, at Daniel.Syal@nola.gov or call the mainline (504) 658-7051.



NOT VALID UNLESS POSTED ON SITE

By posting this notice, the owner of the property certifies that they understand all work described above, and acknowledge that they are legally responsible for ensuring that all work performed has been approved prior to execution and is completed in accordance with approvals obtained. *** For questions regarding this approval or to schedule a final inspection call the number below ***

THIS FORM MUST REMAIN POSTED UNTIL WORK IS CERTIFIED AS COMPLIANT BY HDLC STAFF

1300 Perdido Street, Room 7W03 • New Orleans • LA • 70112 • (504) 658-7040 • www.nola.gov/hdlc

SOLO EL TRABAJO DESCRITO ANTERIORMENTE PUEDE REALIZARSE LEGALMENTE EN ESTE EDIFICIO

608 Sixth St

22-32148-HDLC

12/16/2022

OWNER: NEKA LYNN HIGHLAND

APPLICANT: JEFFREY DAVID CANTIN

ISSUED BY: WENDY CARGILE