

C. ANDERSON CONSTRUCTION / 7926 FRERET ST -

Charles Anderson <candersonconstruction@yahoo.com>

Thu 12/15/2022 2:40 PM

To: Warren E. Jones <Warren.Jones@nola.gov>

EMAIL FROM EXTERNAL SENDER: DO NOT click links, or open attachments, if sender is unknown, or the message seems suspicious in any way. DO NOT provide your user ID or password. If you believe that this is a phishing attempt, use the reporting tool in your Outlook to send this message to Security.

Mr Warren,
I believe we are just waiting on you now.
I have confirmed the two following comments!

PLAN REVIEW WIND
SPEED: The City of New Orleans requires structures be designed for 130 mph basic wind speed. Please confirm.

Plan Review

Open

PLAN REVIEW GLAZING: Provide wind-borne debris protection for exterior glazing in accordance with 2015 IRC, Sec. R301.2.1.2. Glazed opening protection shall meet the requirements of the Large Missile Test of ASTM E 1996 and ASTM E 1886. (Exception: Wood structural panels with a minimum thickness of 7/16" (11 mm) and a maximum span of 8 feet shall be permitted for opening protection in one- and two-story buildings. Panels shall be precut, predrilled, attached to the framing surrounding the opening and secured as per 2015 IRC, Sec. R301.2.1.2.) Please confirm.

Thanks,
Sheri

C. ANDERSON CONSTRUCTION, LLC
"for all your building needs"

Office: 504-834-6209
Fax: 504-835-3976